

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
SEP 9 1965
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 19/1W-6

State Permit No. **LANE**

(1) OWNER:

Name Pleasant Hill School District #1
Address Rt. 2
Creswell, Oregon

(2) LOCATION OF WELL:

County Lane Driller's well number _____
1/4 Section 6 T. 19S R. 14W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 38' 7" ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay & cement
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 8/24/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level **019499**

Was a pump test made? Yes No If yes, by whom? US
Yield: 20 gal./min. with 160 ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand & gravel	0	25
Sand & gravel cemented	25	32
Bedrock	32	35
Bedrock--blue	35	55
Bedrock--blue, sticky	55	65
Grayish bedrock	65	70
Hard clay--gray	70	78
Hard bedrock	78	95
Blue bedrock	95	100
Gray bedrock	100	150
Gray clay & sand	150	160
Redish grayish clay	160	180
Gray, sticky clay	180	200

Work started 7/2/65 19 _____ Completed 7/24/65 19 _____
Date well drilling machine moved off of well 7/24/65 19 _____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Company
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 695, Creswell, Oregon

Drilling Machine Operator's License No. 423

[Signed] Delbert S Jones
(Water Well Contractor)

Contractor's License No. 103 Date 8/26/65, 19 _____