ORIGINAL
File Original and Duplicate with the STATE ENGINEER, SALEM, OREGON

G 479

RECEIVED
JUL 30 1957
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

LANE 020410

State Well No. 19/3w-4F(1)

State Permit No. G 339

(1) OWNER:
Name Oregon State Game Commission
Address Rt 1 Box 325
Corvallis, Ore

(2) LOCATION OF WELL:
County Lane Owner's number, if any—
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☑
~~12~~ " Diam. from ____ ft. to ____ ft. Gage ____
6 " Diam. from 0 ft. to 72 ft. Gage Std
" Diam. from ____ ft. to ____ ft. Gage ____

(7) PERFORATIONS:
Perforated? ☑ Yes ☐ No
Type of perforator used
SIZE of perforations 8 in. by 1/8 in.
30 perforations from 30 ft. to 72 ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.

(8) SCREENS:
Well screen installed ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. ____ Slot size ____ Set from ____ ft. to ____ ft.
____ Slot size ____ Set from ____ ft. to ____ ft.

(9) CONSTRUCTION:
Was well gravel packed? ☑ Yes ☐ No Size of gravel: pea ½"
Gravel placed from 30 ft. to 70 ft.
Was a surface seal provided? ☑ Yes ☐ No To what depth? 30 ft.
Material used in seal— shale, mud, drill cuttings
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 6 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by: OREGON STATE GAME COMMISSION
[Signed] John B. Dimmock (Owner) Date 6-30-, 1957
CHIEF, SUPPLY AND PROPERTY

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: 60 gal./min. with 84 ft. drawdown after 4 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:
Diameter of well 6" inches.
Depth drilled 125 ft. Depth of completed well 125 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Soil	0'	20'
Brownish red, shale, soft	20'	70'
Sandy shale, very soft	70'	72'
Sandstone	72'	125'

Work started June 29 1957 Completed July 6 1957

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Tolbert S Jones (Person, firm, or corporation) (Type or print)
Address Box 695 Rt 2 Creswell
Driller's well number
[Signed] Tolbert S Jones (Well Driller)
License No. 103 Date July 12, 1957

(USE ADDITIONAL SHEETS IF NECESSARY)