NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED DEC 1 1978 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

NC LANE 020490

State Well No. 19s/3w-13c
State Permit No.

(1) OWNER:
Name Emerald Valley Golf Club
Address 83293 Dale Kuni Rd
Creswell, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☒ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
10" Diam. from +1 ft. to 112 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations in. by in.
700 perforations from 41 ft. to 109 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 60 gal./min. with 40 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland Cement Type III
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 19 sacks
How was cement grout placed? Pumped From Bottom

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number 1351/22W
¼ SW ¼ Section 13 T. 19S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 32 ft.
Static level 21 ft. below land surface. Date 10/23/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 10"
Depth drilled 112 ft. Depth of completed well 112 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Sandy Top Soil	0	3	
Large Gravel & Clay Mix	3	18	
Sandy Yellow Caly & Gravel	18	27	
Yellow Clay	27	37	21
Brown Clay & Gravel	37	45	21
Yellow Sandy Clay	45	60	21
Sand & Gravel	60	112	21

Work started 10/2/ 1978 Completed 10/23/ 1978
Date well drilling machine moved off of well 10/23/ 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] (Drilling Machine Operator) Date 10/23/, 1978
Drilling Machine Operator's License No. 652

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Carter's Drilling & Pump Service (Person, firm or corporation) (Type or print)
Address P.O. Box 46-Springfield, Oregon 97477
[Signed] [illegible] (Water Well Contractor)
Contractor's License No. 126 Date 10/23/, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119