NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
DEC 11 1978
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(please type or print)
(Do not write above this line)

LANE
020491

NC

State Well No. 19S/3W-13c

State Permit No.

(1) OWNER:
Name Emerald Valley Golf Course
Address 83293 N. Dale Kuni Road
Creswell, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
8 " Diam. from +1 ft. to 116 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Torch
Size of perforations 1/4 in. by 4 in.
1020 perforations from 32 ft. to 115 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 60 gal./min. with 60 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland Cement Type III
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 32 sacks
How was cement grout placed? Pumped From Bottom up

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number 1351/22
¼ SW ¼ Section 13 T. 19S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 37 ft.
Static level 15 ft. below land surface. Date 11/3/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 8"
Depth drilled 118 ft. Depth of completed well 118 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Sandy Topsoil	0	4	
Yellow Sandy Clay	4	8	
Sand - Gravel - Clay	8	16	
Clay - Large Gravel & Sand	16	22	
Blue Clay	22	27	
Yellow Clay & Gravel	27	30	
Sandy Clay & Gravel	30	70	15
Yellow Clay & Gravel	70	110	15
Greysandy Clay	110	118	15

Work started 10/23/ 1978 Completed 11/3/ 1978
Date well drilling machine moved off of well 11/3/ 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] (Drilling Machine Operator) Date 11/3/, 1978
Drilling Machine Operator's License No. 652

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Carter's Drilling & Pump Service
(Person, firm or corporation) (Type or print)
Address P.O. Box 46-Springfield, Oregon/97477
[Signed] (Water Well Contractor)
Contractor's License No. 126 Date 11/3/, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119