RECEIVED

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

JAN 2 4 1986

020500 WATER PESOUPCES OF DERIF IN INK

)	(for official use		•••
	1	ţ	

SALEM, OREGON	(for official use only)
(1) OWNER:	(10) LOCATION OF WELL by legal description;
Name CITY OF CRESWELL	County LANE 4 4 of Section 14 of
Address 13 S 1 S	Township 195, Range 3 M, WM.
City CROSWELL State ORC	(Township is North or South) (Range is East or West) Tax Lot Lot Block Subdivision
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address)
	WELL Field - WELL # 15
New Well Deepening ☐ Reconditioning ☐ Abandon ☐ If abandonment, describe material and procedure in Item 12.	
	(11) WATER LEVEL of COMPLETED WELL:
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 47, ft.
Thermal:	Static level /6 ft. below land surface. Date 7/15
Rotary Mud Dug Irrigation Withdrawal Reinjection Other:	Artesian pressure lbs. per square inch. Date
Cable Bored Piezometric Grounding Test	
(5) CASING INSTALLED: Steel Plastic	Depth drilled /30 ft. Depth of completed well /30 ft.
Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show thickness
6 Diam. from + 2 ft. to 13.0 ft. Gauge 250	and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal
Tit. to ft. Gauge ft.	water-bearing strata.
LINER INSTALLED: Steel Plastic Threaded Welded	MATERIAL From To SWL
-	Eug. 0 3
"Diam. fromft. toft. Gauge	REDUN CLAY W/SMALL GRAVE 3 47
(6) PERFORATIONS: Perforated? ☐ Yes ☐ No	SMALL GRAVE & SAND 47 49 WB
Size of perforations 2 /2 in. by 1/4 in.	BROWN CLAY, SMALL GRAVE, SAND 49 70
perforations from	L+ BROWN Clay 70 14
perforations from 74 ft. to 79 ft.	SMALL GRAVEL SAND, SANDY C/AY 74 76 WB
2_3_5perforations from	77 92
(7) SCREENS: Well screen installed? Yes	BLUE CLAY, GRAVEL &SAND 92 104
Manufacturer's Name	BLUE / BONIN CLAY, GRAVE (SAN 104 11)
Type	COARSO SAIN PER GRAVE 1113 123 WB
Diam Slot Size Set from ft. to ft.	CORRSE SAND, PEA GRAVE 113 123 WB CORRSE SAND, Some PEA GRAVE 123 126
Diam Slot Size Set from ft. to ft.	SAND, SMALL Amounts of CAMIN 26 129
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Cemented PEAGRACUL W/9EAY- 129 130
Was a pump test made? ☐ Yes ☐ No If yes, by whom?	-CLOY
was a pump test made. I les I le I les in Jee, by whom. gal./min. with ft. drawdown after / hrs.	***************************************
WELL OUT PUT MAY Fluctuate.	·
Air test SO gal./min. with drill stem at 160ft. / hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	2/2/05
(9) CONSTRUCTION: Spacial standards: Yes \(\square\) No \(\bar\)	Date work started / Completed / Completed
Well seal—Material used Cement	Date well drilling machine moved off of well 7/15-19
Well sealed from land surface toft.	(unbonded) Water Well Constructor Certification (if applicable):
Diameter of well bore to bottom of seal in.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	
Amount of sealing materialsacks pounds	[Signed]
How was cement grout placed? Dumpes they termine	(bonded) Water Well Constructor Certification;
to Surther	Bond 662 655-2 Issued by: TRAVELENS (Surety Company Name)
4CM13	On behalf of Christensen Well Delling Co
Was pump installed? JES Type Control of Depth 102ft.	(type or print name of Water Well Constructor)
Was a drive shoe used? Wes No Plugs Size: location ft. Did any strata contain unusable water? Yes No	This well was drilled under my jurisdiction and this report is true to the
Type of Water? depth of strata	best of my knowledge and belief:
Method of sealing strata off	(Signed) Vaul Christersen, J-Pres
Was well gravel packed? Yes No Size of gravel:	(Water Well Constructor)
Gravel placed fromft. toft.	(Dated)