

WATER WELL REPORT
STATE OF OREGON

RECEIVED

NOV 16 1983

State Well No. 195/5W-2426

PLEASE TYPE OR PRINT IN INK WATER RESOURCES DEPT. OREGON

State Permit No. LAN 5021225

(1) OWNER:

Name Chuck Scoggins
Address 28235 Briggs Hill Rd
City Eugene State Or

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
Cased Bored Thermal: Withdrawal Reinjection

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
6" "Diam. from +1 ft. to 39 ft. Gauge 2.50
"Diam. from ft. to ft. Gauge

(6) LINER INSTALLED:

"Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
..... gal./min. with ft. drawdown after hrs.
Air test 100 gal./min. with drill stem at 170 ft. 1+ hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used CEMENT
Well sealed from land surface to 39 ft.
Diameter of well bore to bottom of seal 11 in.
Diameter of well bore below seal 6 in. at 17
Number of sacks of cement used in well seal 17 sacks
How was cement grout placed? pumped down in 1" pipe
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 23-83
NW 1/4 SE 1/4 Section 24 T. 19S R. 5W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 28235 Briggs Hill Rd
Eugene Or

(11) WATER LEVEL: Completed well.

Depth at which water was first found 100 ft.
Static level 8' 11" ft. below land surface. Date 11-4-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 170 ft. Depth of completed well 170 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Dirt	0	2	
Clay	2	15	
Sandstone (Brown)	15	25	
Blue Sand Stone	25	170	8' 11"

The water was found in cracks in the sand stone from 100' to 170'

Work started 11-1-1983 Completed 11-3-83
Date well drilling machine moved off of well 11-3-83 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Art Holte Date 11-14-1983

Bonded Water Well Constructor Certification:

Bond 800174 Issued by Contractors Bonding Co
(number) Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Art Holte (Type or print)
Address PO-Box 148 Elmira Co-97437
[Signed] Art Holte Water Well Constructor
Date 11-14-83

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*45292-690