

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

DEC 20 1965 WATER WELL REPORT

WELL NO. 1)

LANE 021284

State Well No. 19/76-19

STATE ENGINEER, SALEM, OREGON 97310 STATE ENGINEER, SALEM, OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name Dept. of the Interior
Address Bureau of Land Management-Dist. Office
P. O. 392 - Eugene, Oregon

(2) LOCATION OF WELL:

County Lane Driller's well number
1/4 Section NE T. 19S R. 7W W.M.
Bearing and distance from section corner Section

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Rotary [] Driven []
Irrigation [] Test Well [x] Other [x] Cable [x] Jetted []
Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded [] Welded [x]
6" Diam. from 0 ft. to 20 ft. Gage 19lb.

(7) PERFORATIONS:

Perforated? [] Yes [x] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement
Depth of seal 18 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [] Yes [x] No
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 9 ft. below land surface Date 11/15/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [x] No If yes, by whom?
Field: gal./min. with ft. drawdown after hrs.
Bailer test 6 gal./min. with 70 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 85 ft. Depth of completed well 85 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Top soil (0-4), Yellow clay (4-13), Gray sandstone (13-85).

Work started 11/6/65 19 Completed 11/15/65 19
Date well drilling machine moved off of well 11/15/65 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. W. Drilling and Pump Service
(Person, firm or corporation) (Type or print)

Address 4157 Main St. Springfield, Ore.

Drilling Machine Operator's License No. 404

[Signed] Walt Wilson (Water Well Contractor)

Contractor's License No. 268 Date 12/10/65 19