NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date

R

WATER WELL REPORT

STATE OF OREGON (Please type or print)

021642 State Well No. 195/12W-34ba

of well completion. (Do not write above this line)

(1) OWNER:	(10) LOCATION OF WELL:
Name Siltcoos Lake Resort	County Lane Driller's well number 01+0180K
Address PO Box 36	NW 14 NG 14 Section 34 T. 19 SR. 12W W.M.
Westlake, Or. 97493	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well ☐ Deepening ☐ Reconditioning ☑ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Don't at which were seen that a
Rotary Driven Domestic Industrial Municipal	
Description Test Well Other	Static level 30 ft. below land surface. Date 1/24/8 Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded William	(19) WELLIOC.
	Diameter of well below casing
ft. Gage ft. to	
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
(6) PERFORATIONS: Perforated? Tilyes Fil No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	_ Previous
perforations from ft. to ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	2.:27.21.1.22
(7) SCREENS: Well screen installed? ☑ Yes □ No	drilled 4 holes around caking
Manufacturer's Name Previous	to 18', then filled with cement. Put bailer into hole and removed
Type Model No.	considerable silt, but water
Diam Slot size Set from ft. to ft.	cleared up very well after
Diam Slot size Set from ft. to ft.	pumping.
(O) XXXXI X PROCESS Drowdown is second to the land	Also extended casing above ground.
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	DECEMEN
s a pump test made? 🛛 Yes 🗆 No If yes, by whom? KK 💍 JJ &	K NAEULIALD
Yield: 25 gal./min. with 0 ft. drawdown after 1 hrs.	FFD.9.0 1000
" " " "	1 E D 13 O 1000
" " "	WATER RESOURCES DEPT
iler test gal./min. with ft. drawdown after hrs.	SALEM, OREGON
Temperature of water 52Depth artesian flow encountered ft.	
1cmpcrature of water)2 Depth artesian now encountered ft.	Work started 1/21 19 80 Completed 1/24 1980
(9) CONSTRUCTION:	Date well drilling machine moved off of well 1/24 1980
Well seal—Material used cement	Drilling Machine Operator's Certification:
Well sealed from land surface to18ft.	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal 18 in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Dent Yashing Operator) Date 1/28, 1980
Number of sacks of cement used in well seal 21 sacks	(— mang adayama operator)
How was cement grout placed?pumped	Drilling Machine Operator's License No. 1337
11.00	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? 🗌 Yes 🗍 No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	Name JJ & K Well Drilling (Person, firm or groporation) (Type or print)
Type of water? depth of strata	Address PO Box 811 Florence, Or. 97439
Method of sealing strata off	111/400
Was well gravel packed? Yes No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from ft. to ft.	737 7 1/28/ 80
Δυ,	Contractor's License No Date