

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97300
within 30 days from the date
of well completion.

WATER WELL REPORT

RECEIVED

RECEIVED

JUL - 5 1977

STATE OF OREGON
(Please type or print)

AUG 10 1977

State Well No. 205/3W-32
LANE
State Permit No. 022410

(Do not write above this line)

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER: WATER RESOURCES DEPT.
Name Mr. Gorman Wright SALEM, OREGON
Address 241 Talemna Drive
Cottage Grove, OR 97424

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

(5) CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 50 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
d: gal./min. with ft. drawdown after hrs.
" " " " "
Tested by Air (Est. could fluctuate) "
Baker test 60 gal./min. with 121 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 49 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? Poured
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number
1/4 1/4 Section 32 T. 20S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 60 ft.
Static level 29 ft. below land surface. Date 6/16/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 150 ft. Depth of completed well 150 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	3	
Yellow brown clay	3	32	
Brown clay	32	35	
Blue gray cong.	35	42	
Brown sandstone	42	46	
Blue gray cong.	46	76	
Gray brown sandstone	76	101	
Blue gray sandstone	101	150	

Work started 6/15 19 77 Completed 6/16 19 77
Date well drilling machine moved off of well 6/16 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] *Frankie Smith* Date 6/16, 19 77
(Drilling Machine Operator)
Drilling Machine Operator's License No. 979

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Casey Jones Well Drilling Co., Inc.
(Person, firm or corporation) (Type or print)
Address 37115 Immigrant Road, Pleasant Hill, OR
[Signed] *Casey Jones*
(Water Well Contractor)
Contractor's License No. 559 Date 6/16 19 77