

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED

LANE WATER WELL REPORT

STATE OF OREGON MAY 22 1975

State Well No. 205/3W-31

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Please type or print) STATE ENGINEER
SALEM, OREGON

022415

(Do not write above this line)

(1) OWNER:

Name Goodman Wright
Address 917 Sweet Lane Cottage Grove, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Aug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

6" Diam. from 0 ft. to 74 ft. Gage .250
Threaded Welded

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 15 gal./min. with 71 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 72 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 13 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number
¼ ¼ Section 32 T. 20S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 101 ft.
Static level 79 ft. below land surface. Date 5/15/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 150 ft. Depth of completed well 150 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Brownish Red Clay	1	11	
Yellow Brown Clay	11	32	
Brown Clay & Boulders	32	58	
Brown Claystone	58	66	
Gray Sandstone	66	92	
Blue Gray Cong.	92	114	
Blue Gray Sandstone	114	150	

Work started 5/14/75 19 Completed 5/15/75 19
Date well drilling machine moved off of well 5/15/75 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Casey L. Jones Date 5/15/75, 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 521

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Casey Jones Well Drilling Co., Inc.
(Person, firm or corporation) (Type or print)
Address Rt 8 Box 695 Pleasant Hill, Oregon
[Signed] Casey L. Jones
(Water Well Contractor)
Contractor's License No. 559 Date 5/15/75, 19