

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

STATE OF OREGON JUN 12 1975

State Well No. 205 / 3W - 31

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Please type or print)

STATE ENGINEER
SALEM, OREGON

State Permit No. _____

022416

(1) OWNER:

Name Gorman Wright
Address 241 Talemena Drive
Cottage Grove, Oregon 97424

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 80 ft. Gage .250
" Diam. from " ft. to " ft. Gage "
" Diam. from " ft. to " ft. Gage "

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
x Delay test 8 gal./min. with 291 ft. drawdown after 1 hrs.

Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 69 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 13 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County _____ Lane _____ Driller's well number _____
1/4 1/4 Section 32 T. 20S R. 3W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 91 ft.
Static level 54 ft. below land surface. Date 5/24/75
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 345 ft. Depth of completed well 345 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|--------------------------|------|-----|-----|
| Top Soil | 0 | 2 | |
| Red Brown Clay | 2 | 10 | |
| Brown Clay | 10 | 12 | |
| Yellow Brown Clay | 12 | 14 | |
| Light Brown & White Clay | 14 | 21 | |
| Yellow Clay | 21 | 38 | |
| Yellow Brown Clay | 38 | 45 | |
| Blueish Brown Sandstone | 45 | 78 | |
| Green Cong. | 78 | 103 | |
| Blue Gray Cong. | 103 | 290 | |
| Red Cong. | 290 | 327 | |
| Blue Cong. | 327 | 345 | |

Work started 5/24/75 19 Completed 5/27/75 19
Date well drilling machine moved off of well 5/27/75 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Al. K. Jones Date 5/27/75, 19____
(Drilling Machine Operator)

Drilling Machine Operator's License No. 702

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Casey Jones Well Drilling Co., Inc.
(Person, firm or corporation) (Type or print)

Address 37115 Immigrant Rd. Pleasant Hill, Oregon

[Signed] Casey J. Jones
(Water Well Contractor)

Contractor's License No. 559 Date 5/27/75, 19____