

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT RECEIVED

STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No. 200/3E-33

JAN 31 1977

State Permit No. LANE

WATER RESOURCES DEPT.

022899

(1) OWNER:

Name High Prairie Villa #1
Address 49696 High Prairie Villa
Oakridge, OR 97463

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 54 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Well: gal./min. with ft. drawdown after hrs.
" " " " " " " "
Tested by Air (Est. could fluctuate) " "
Boiler test 23 gal./min. with 259 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement grout
Well sealed from land surface to 53 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 12 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number
¼ Section 35 T. 20S R. 3E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 181 ft.
Static level 91 ft. below land surface. Date 12/30/76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 350 ft. Depth of completed well 350 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Red Brown Clay & Boulders	2	28	
Yellow Brown Clay & Bould.	28	48	
Blue gray sandstone	48	67	
Red black cinder w/clay	67	73	
Blue gray sandstone	73	116	
Redblack cinder w/clay	116	129	
Blue gray sandstone	129	148	
Redblack cinder w/clay	148	157	
Blue gray sandstone	157	214	
Redblack cinder w/clay	214	241	
Blue gray sandstone	241	279	
Redblack cinder w/clay	279	293	
Blue gray sandstone	293	324	
Black cinder w/clay	324	331	
Blue gray sandstone	331	350	

Work started 12/27 1976 Completed 12/31 1976
Date well drilling machine moved off of well 12/31 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Annini L. Smith Date 12/31, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 979

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Casey Jones Well Drilling Co., Inc.
(Person, firm or Corporation) (Type or print)

Address 37115 Immigrant Road, Pleasant Hill, OR

[Signed] Casey Jones
(Water Well Contractor)

Contractor's License No. 559 Date 12/31, 1976