NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

## WATER WELL REPORT

STATE OF OREGON

MAY 2 2 1977

State Well No. 215/361-90

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the day of well completion.

(Please type or print)

(Do not write above this ningER RESOURCES DEPT.

CALEM. OREGON (1) OWNER: (10) LOCATION OF WELL: Riverstone Mobile Park Name Driller's well number 3062-CP 77500 S. 6th Address 1/4 Section 9 T. 21s R. W.M. Cottage Grove. Oregon Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): New Well IX Deepening [ Reconditioning [ Abandon | If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Rotary Driven 📋 Domestic 🛣 Industrial 🗌 Municipal 🖂 Static level ft. below land surface. Cable Jetted | Dug Bored Irrigation | Test Well | Other Artesian pressure lbs. per square inch. Date CASING INSTALLED: Threaded [] (12) WELL LOG: Diameter of well below casing ... Diam. from +1 ft. to 39 ft. Gage •2 Depth drilled 750 ft. Depth of completed well Formation: Describe color, texture, grain size and structure of materials; ..." Diam. from ...... ft. to ..... ft. Gage ..... and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in PERFORATIONS: position of Static Water Level and indicate principal water-bearing strata. Perforated? Tyes X No. Type of perforator used MATERIAL Size of perforations in. by Top Soil Brown Clay 23 ...... perforations from ....... ft. to ..... ft. Blue Clay ...... perforations from ...... ft. to ..... ft. Grey Sandstone 28 12 97 perforations from \_\_\_\_\_ ft. to \_\_\_\_ Blue Shale 97 11:6 (7) SCREENS: Well screen installed? 
Yes X No Soft Blue Shale Manufacturer's Name ..... Diam. ..... Slot size ...... Set from ..... ft. to ..... ft. Diam. ..... Slot size ...... Set from ..... ft. to ..... ft. (8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? X Yes \( \subseteq No \) If yes, by whom? **Driller** gal./min. with 128 ft. drawdown after 1 Bailer test No gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. erature of water Depth artesian flow encountered ..... 4-21 4-23 Work started 1977 Completed Date well drilling machine moved off of well (9) CONSTRUCTION: 1977 Portland Cement Well seal-Material used ..... Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge artibelief.

[Signed]

(Drilling Machine Operator)

Date 1-30, 19 77 Well sealed from land surface to ..... Diameter of well bore to bottom of seal . Number of sacks of cement used in well seal 25
How was cement grout placed? Mixed 5 gal water per Drilling Machine Operator's License No. ..... sack - pumped in place with grout pump down Water Well Contractor's Certification: drop pipe This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Was a drive shoe used? 🗌 Yes 🔀 No Plugs ....... Size: location ...... ft. Name Carter 5 ...

(Person, firm or corporation)

Address P.O. Box 16 Springfield Carter's Drilling and Pump Service Did any strata contain unusable water? 

Yes X No (Type or print) Type of water? Method of sealing strata off [Signed] Was well gravel packed? [ Yes X No Size of gravel: ..... Contractor's License No. 126 Date 4-30 , 19.77 Gravel placed from ...... ft. to .....