NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report

are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE: OF OREGON

(Please type or print)

 023339^{s}

3 State Well No. 215/3E - 16d

(Do not write above this line)

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name City of Oakridge	County Lane Driller's well number #7]
Address 48318 - 1st	1/4 S.E. 1/4 Section 16 T. 21 R. 3E W.M.
Oakridge, Oregon	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well 🛣 Deepening 🗆 Reconditioning 🗅 Abandon 🖂	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	1 _ n _ n _ n _ n _ n _ n _ n _ n _ n _
Rotary Driven Domestic	Static level 47 ft. below land surface. Date 5/30/79
Cable Dug Bored D Irrigation Test Well L Other D	
	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing 811
8 "Diam. from +2 ft. to 210 ft. Gage 288	Depth drilled 235 ft. Depth of completed well 230 ft.
ft. Gageft.	Formation: Describe color, texture, grain size and structure of materials:
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? Yes X No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Large Boulders - Cobbles 0 8
perforations fromft. toft.	Sand & Gravel - Large Cobbles 8 20
perforations fromft. toft.	Cemented Sand & Gravel 20 5h h7
perforations fromft. toft.	Brown Soft Sandy Clay 54 58 47
(7) CODERIG.	Brown Course Sand/Clay Cemented 58 76 47
(7) SCREENS: Well screen installed? Yes I No Johnson	Course Sand Gravel Heavey Clay 76 82 47
Type Low Carbon Model No. Telescope	Brown Course Sand & Gravel 82 108 47
Diam. 8 Slot size 60 Set from 70 ft. to 200 ft.	Sand Gravel 108 110 47 Brown Course Sandy Clay 110 165 47
Diam. Slot size Set from ft. to ft.	Brown Course Sandy Clay 110 165 47 Fine Sand Gravel Some Clay 165 190 47
	sand Fine Gravel Small Gravel 190 200 47
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Sand Brown Clay, Some Gravel 200 235 47
Was a pump test made? X Yes No If yes, by whom? Carter's	
Yield: 315 gal./min. with 15 ft. drawdown after 8 hrs.	K G M M M M M M M M M M M M M M M M M M
" " "	
" " " "	プロー かり は
Bailer test no gal./min. with ft. drawdown after hrs.	WATER RESOURCES DEP
Artesian flow g.p.m.	SALEM, OREGON
perature of water 51 Depth artesian flow encounteredft.	Work started 4/23/ 19 79 Completed 5/30/ 19 79
position of which a deposit at residuit flow encountered	
(9) CONSTRUCTION:	Date well drilling machine moved off of well 5/30/ 19 79
Well seal—Material used Portland Cement Type III	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below sealin.	[Signed] June Javellate 5/30/, 19 79
Number of sacks of cement used in well seal sacks How was cement grout placed? Method "C" Used	Drilling Machine Operator's License No. 1009
now was cement grout placed?	The state of the s
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? ♣ Yes □ No Plugs Size: location ft.	true to the best of my knowledge and belief. Name Carter's Drilling & Pump Service
Did any strata contain unusable water? Yes No	Name Carter's Drilling & Pum Service (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address P.O. Box 46 Springfield, Oregon 97477
Method of sealing strata off	
Was well gravel packed? Yes No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from ft to #	Contractor's License No. 126 Date 5/30/