

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
MAR 10 1965

WATER WELL REPORT

LANE

023522

2 1/2 - 11

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

State Permit No. _____

OWNER:

SALEM OREGON

Willamette National Forest
P. O. 1272 (Box)
Eugene, Oregon

(2) LOCATION OF WELL:

County Lane Driller's well number
1/4 Section 2-11 T. 21S R. 2E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 37.5 ft. Gage 191b.
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement & bentonite
Depth of seal 35 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 14' 8" ft. below land surface Date 2,23,65
Artesian pressure lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? W.W. Drilling
Yield: 20 gal./min. with 135 ft. drawdown after 3 hrs.
" 18 " 135 " 2 "
" 17.6 " 135 " 3 1/2 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 169 ft. Depth of completed well 169 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil, brown loam	0	14
Boulders	14	19
Cemented gravel	19	170 24
Claystone, blue grey	24	170

Work started 2-8-65 19 Completed 2-24-65 19
Date well drilling machine moved off of well 2-24-65 19

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. W. Drilling and Pump Service
(Person, firm or corporation) (Type or print)
Address 4157 Main St. Springfield, Oregon

Drilling Machine Operator's License No. 358

[Signed] *Walt Wilson* (Water Well Contractor) *W*

Contractor's License No. 268 Date 3/3/65, 19