

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
SEP 5 - 1972
STATE ENGINEER
SALEM, OREGON
STATE OF OREGON
WATER WELL REPORT
(Please type or print)(Do not write above this line)

LANE State Well No. **213/2E-12b**
023530 State Permit No. _____

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(1) OWNER:
Name **OAKRIDGE SCHOOL (RW)**
Address **OAKRIDGE, OREGON**

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 22 ft. Gage 250
8" Diam. from 22 ft. to 49 ft. Gage 375
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from ft. to ft.
_____ perforations from ft. to ft.
_____ perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test **75** gal./min. with **36** ft. drawdown after **2** hrs.
Artesian flow g.p.m.
Temperature of water **50**° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used **PORTLAND CEMENT**
Well sealed from land surface to **49** ft.
Diameter of well bore to bottom of seal **14** in.
Diameter of well bore below seal **8** in.
Number of sacks of cement used in well seal **12** sacks
Number of sacks of bentonite used in well seal **-0-** sacks
Brand name of bentonite **-0-**
Number of pounds of bentonite per 100 gallons
of water **-0-** lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County **LANE** Driller's well number **52028/22**
Section **12** T. **21** R. **2E** W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found **87** ft.
Static level **14** ft. below land surface. Date **8-16-72**
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing **8 (7 1/4)**
Depth drilled **97** ft. Depth of completed well **97** ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY TOP SOIL	0	4	
LARGE BOULDERS	4	18	
SAND, GRAVEL WITH LARGE COBBLES	18	44	
LIGHT BLUE SHALE	44	87	
HARD GREY ROCK	87	97	14

Work started **8-5-72** 19 Completed **8-17-72** 19
Date well drilling machine moved off of well **8-18-72** 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] *Arthur N. Lewis* Date **8-23-72**, 19____
(Drilling Machine Operator)
Drilling Machine Operator's License No. **717**

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name **CARTER'S DRILLING & PUMP SERVICE**
(Person, firm or corporation) (Type or print)
Address **325 S.O. 2ND ST. SPRINGFIELD, OREGON**
[Signed] *James G. Carter*
(Water Well Contractor)
Contractor's License No. **126** Date **8-23-72**, 19____