

RECEIVED

LANE 023757

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE OF OREGON WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 22/1W-156

State Permit No.

(1) OWNER:

Name US Dept of Interior
Address Bureau Land Management
PO Box 392 Eugene Oregon

(2) LOCATION OF WELL:

County LANE Driller's well number 41
SW 1/4 NE 1/4 Section 15 T. 22S R. 1W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Rotary [] Driven []
Irrigation [] Test Well [] Other [x] Cable [x] Jetted []
Dug [] Bored []
PARK

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded [] Welded [x]
6" Diam. from 0 ft. to 21 ft. Gage #
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [] Yes [x] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [x] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 18 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [] Yes [x] No
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 17 ft. below land surface Date 11-29
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [x] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
" " " "
Baller test 14 gal./min. with 31 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 44 Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 94 ft. Depth of completed well 94 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows: Soil Red (0-1), Gravel coarse (1-15), Sandstone yellow (15-30), LAVA - Red (30-59), Sandstone white (59-94)

Work started 11-23 1962 Completed 11-27 1962
Date well drilling machine moved off of well 11-27 1962

(13) PUMP:

Manufacturer's Name DEMPSTER
Type: HAND PUMP H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Boehrs + WALTON (Person, firm or corporation) (Type or print)

Address PO Box 414 Oakland Ore

Drilling Machine Operator's License No. 29-30

[Signed] Floyd J Walton (Water Well Contractor)

Contractor's License No. 267 Date 19