NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT LANE

STATE OF OREGON

175/3W-Z	isdcb
----------	-------

(Please type or print)
(Do not write above this line)

52060 State Well No. State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:
Name Chase Gardens	County Lane Driller's well number
Address P.O. Box 59	14 14 Section 28 T. 17S R. 3W W.M.
Eugene, Oregon	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing 10
Rotary Driven Domestic Industrial Municipal Domestic Industrial Municipal	Depth drilled 21 ft. Depth of completed well 84 ft.
Dug Bored Irrigation Test Well Other	Formation: Describe color, texture, grain size and structure of materials;
(5) CASING INSTALLED: Threshed welded 23	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change
10 " Diam. from 63 ft. to ft. Gage 33	in position of Static Water Level as drilling proceeds. Note drilling rates.
" Diam, from ft. to ft. Gage	MATERIAL From To SWL
" Diam, from ft. to ft. Gage	Sand - Gravel - Large Cobbles
(6) PERFORATIONS: Perforated? △ Yes □ No.	3 63 66
Type of perforator used Mills Knife	Sand - Gravel - Mixed
Size of perforations 3/8 in. by 3 in. 6	Heavy With Clay 66 72
Mills Knife 25 tt. to 52 tt.	Soft Blue Shale 8 72 80
perforations from ft. to ft.	
ft. to ft.	Blue - Hard Shale 4 80 84
perforations from ft. to ft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? Yes Y No	
Manufacturer's Name	O D N
Type Model No.	60PY
Diam. Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
Static level $20\frac{1}{2}$ ft. below land surface Date $8/4/59$	
Artesian pressure lbs. per square inch Date	
(9) WELL TESTS. Drawdown is amount water level is	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes No If yes, by whom?	Work started 7/30/ 19 59 Completed 8/4/ 19 59
Yield: gal./min. with ft. drawdown after hrs.	Date well drilling machine moved off of well 19
" " " " "	
" " " " " " " " " " " " " " " " " " "	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
Temperature of water Was a chemical analysis made? Yes No	[Signed]
(10) CONSTRUCTION:	Drilling Machine Operator's License No.
Well seal—Material used	Drining Machine Operator's Dicense 170.
Depth of seal ft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal in.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Were any loose strata cemented off? Yes No Depth	
Was a drive shoe used? Yes No	NAME CARTER'S DRILLING & PIMP SERVICE (Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes No	Address 325 So. 2nd St., Springfield, Oregon.
Type of water? depth of strata	, -I
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	
Gravel placed from ft. to ft.	Contractor's License No. 126 Date 8/28/ 19.59.