

Well ID # L38902

(START CARD) # 85435

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(as required by ORS 537.365)lane  
58-446

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number well #6Name Springfield Utility Board  
Address 202 S. 18th  
City Springfield State Ore. Zip 97477(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other Municipal(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 62 ft  
Explores used  Yes  No Type AM Access

HOLE			SEAL			Sacks or pounds
Diameter	From	To	Material	From	To	
20"	0'	20.5'	Bentonite	0'	24.5'	42 SACKS
16"	20.5'	62'				

How was seal placed: Method  A  B  C  D  H  
 Other Devised - probed as 20" pipe removed  
Backfill placed from      ft. to      ft. Material       
Gravel placed from      ft. to      ft. Size of gravel     

Casing	Diameter	From	To	Gauge Size	Plastic	Welded	Threaded
	16"	13'	24'	375	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	14"	18'	25'	260	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	14"	18'	20'		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			24'		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

(6) CASING/LINER:							
From	To	Size	Number	Diameter	Material	Casing	Liner
25'	44'	30		14"	PS	<input type="checkbox"/>	<input type="checkbox"/>
44'	54'	60		14"	PS	<input type="checkbox"/>	<input type="checkbox"/>
54'	62'	33		14"	PS	<input type="checkbox"/>	<input type="checkbox"/>

(8) WELLTESTS: Minimum testing time is 1 hour  
 Pump  Walkin  Aer  Flowing Artesian  
Yield/gallon 30 GPM Drawdown 2' (at 10 min)      Time      hrs  
Temperature of water 40° Depth Artesian     Was a water analysis done?  Yes By whom       
Did any strata contain water not suitable for intended use?  Yes  No  
 Salty  Murky  Oily  Colored  Other       
Depth of strata     (9) LOCATION OF WELL by legal description:  
County lane Latitude      Longitude       
Township 17S N or S Range 2W E or W WM  
Section 27 NW 1/4 SW 1/4  
Tax lot 400 Lot      Block      Subdivision       
Street Address of Well (for nearest address) 1351 N. 6th  
Springfield, Ore.(10) STATIC WATER LEVEL:  
9 ft. below land surface Date 6-30-00  
Artesian pressure      lbs per square inch Date     (11) WATER BEARING ZONES:  
Depth at which water was first found 18'

From	To	Estimated Flow Rate	SWI
25'	62'	30+ GPM	9'
<b>RECEIVED</b>			
MAY 4 2001			

(12) WELL LOG:  
WATER RESOURCES DEPT  
SALEM, OREGON

Material	From	To	SWI
Top soil + rock	0'	3'	
Brown sandy clay	3'	8'	
Grey sandy clay	8'	18'	
Large gravel w/ grey sandy clay	18'	23'	
Large - small gravel w/ sand	23'	32'	
Small - large gravel w/ fine - coarse sand	32'	42'	
Small - large gravel w/ brown sand + some clay	42'	54'	
Gravel w/ fine - coarse brown sand	54'	57'	
Gravel w/ brown sand + clay	57'	62'	

Date started April 13, 00 Completed 6-30-00  
(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed      WWC Number      Date     

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed Michael Waldrop WWC Number 633 Date 7-21-00

ORIGINAL &amp; FIRST COPY-WATER RESOURCES DEPARTMENT SECOND COPY-CONSTRUCTOR THIRD COPY-CUSTOMER