

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

LANE
6060

RECEIVED
MAY 19 1967

WATER WELL REPORT ENGINEER

State Well No. 15/HW-17F

STATE OF OREGON
(Please type or print)

G-4047

State Permit No. _____

(1) OWNER:

Name EARNEST EUGENE BOWDEN
Address 1245 NORATON RD.
JUNCTION CITY ORE

(2) LOCATION OF WELL:

County LANE Driller's well number _____
1/4 Section 17 T. 15S R. 4 W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
4" Diam. from 0 ft. to 26 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Acetylene
Size of perforations 1/4 in. by 4 in.
34 perforations from 0 ft. to 21 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 6 ft. Was a packer used? Yes No
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 5/13/67
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 250 gal./min. with 9 ft. drawdown after 2 hrs.
" " " " "
" " " " "
" " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 26 ft. Depth of completed well 26 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil + Brown sandy clay	0	13
packed sand.	13	17
packed sand + gravel	17	22
water bearing gravel course	22	26

Work started 5/13 1967 Completed 5/13 1967
Date well drilling machine moved off of well _____ 19 _____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O. B. NYE (Type or print)
(Person, firm or corporation)
Address JUNCTION CITY ORE
Drilling Machine Operator's License No. 211

[Signed] O. B. Nye
(Water Well Contractor)
Contractor's License No. 151 Date 5/13 1967