STATE	ENGINEER		
Salem, Oregon			



STATE WELL NO. 15/4W-17Q COUNTY Lane APPLICATION NO. GR-934

OWNER: Clarence Edmounds	MAILING ADDRESS:	Rt. 3		
LOCATION OF WELL: Owner's No	CITY AND	Junction City		
SW 1/4 SE 1/4 Sec. 17 T. 15 S., R. 4 W.				
Bearing and distance from section or subdivision				
corner SE cor. Sec. 17 W. 2640' thence N. 3	30!			
to well				

Altitude at well 307 ft.			-(1)	
			a (1)	
TYPE OF WELL: drilled Date Constructed May				
Depth drilled 27 ft. Depth cased 27 ft.		Section	17	-
CASING RECORD: 4 inch steel pipe 0 -	27 ft.			
FINISH:				
AQUIFERS:				
AQUIFERS:				
		and the second s		
WATER LEVEL:		-	•	
PUMPING EQUIPMENT: Type 2½ in. A.C. Capacity 400 G.P.M.	centrifugal		H.P. 15	elec. G.E
WELL TESTS: Drawdown8 ft. after	Lours	400		СЪМ
Drawdown ft. after				CONTRACTOR OF THE PARTY.
USE OF WATER Irrigation SOURCE OF INFORMATION OWNER			~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	, 19
DRILLER or DIGGERADDITIONAL DATA: Log			-	
REMARKS:				