

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

RECEIVED
 WATER WELL REPORT
 APR 14 1967
 STATE ENGINEER
 SALEM, OREGON

LANE
 6088
 State Well No. 15/4w-1
 State Permit No.

(1) OWNER:

Name SOREN MADSEN
 Address W-3
JUNCTION CITY ORE

(2) LOCATION OF WELL:

County LANE Driller's well number 1
1/4 Section 18 T. 15S R. H.W. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
 Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

5" Diam. from 0 ft. to 27 ft. Threaded Welded
 Gage 288
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used Acetylene
 Size of perforations 1/4 in. 4 in.
40 perforations from 22 ft. to 27 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
 Depth of seal 6 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 7 ft. below land surface Date 4/8/67
 Artesian pressure _____ lbs. per square inch. Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Driller
 Yield: 150 gal./min. with 12 ft. drawdown after 2 hrs.
 " " " " "
 " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
 Depth drilled 29 ft. Depth of completed well 27 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil + Brown Sandy Clay	0	11
packed sand + gravel	11	20
Water bearing sand	20	26
+ gravel packed coarse sand	26	29

Work started 4/7 1967 Completed 4/8 1967
 Date well drilling machine moved off of well 4/8 1967

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME O. B. Nye (Person, firm or corporation) (Type or print)
 Address JUNCTION CITY ORE
 Drilling Machine Operator's License No. 211
 [Signed] O. B. Nye (Water Well Contractor)
 Contractor's License No. 151 Date 4/8 1967