NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, ÖREGÖN 97310 within 30 days from the date of well completion.

LANGUATER WELL REPORT ECEIVED

STATE OF OREGON

(Please type or print) STATE ENGINEER

(Do not write above this line) SALEM. OR State Berinit No.

(1) OWNER:	(11) LOCATION OF WELL:	
Name Martin Strome (Well #4)	County Lane Driller's well number	
Address 1425 Hy 99 E, Junction City, Ore. 97448	14 14 Section 19 T. 15S R. 4W	W.M.
(a) mype of work (d. d.).	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):		
New Well 🔀 Deepening 🗆 Reconditioning 🗀 Abandon 🗀		
If abandonment, describe material and procedure in Item 12.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing	O
Cable	Depth drilled 29 ft. Depth of completed well 2	9 ft.
Dug Bored Irrigation T Test Well Other	Formation: Describe color, texture, grain size and structure of	of materials;
CASING INSTALLED: Threaded Welded To Threaded Document Threaded To	and show thickness and nature of each stratum and aquifer with at least one entry for each change of formation. Report in position of Static Water Level as drilling proceeds. Note de	each change
" Diam. from ft. to ft. Gage	MATERIAL From To	[
ft. Gage	soil and sand 0 7	7
DEDECORATIONS.	sand & gravels w/clay 7 24	<u> </u>
PERFORATIONS: Perforated? ☑ Yes □ No.		0.6 6°
Type of perforator used torch		
Size of perforations 3/8 in. by £7 in. 44 perforations from 24 ft. to 29.6 ft.		
perforations fromft. toft.		
perforations fromft. toft.		
perforations from ft. to ft.		
perforations from tt. tott.		
(7) SCREENS: Well screen installed? Yes X No		
Manufacturer's Name		
Type Model No		
Diam Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.		
(8) WATER LEVEL: Completed well.		<u>. </u>
Static level 6 ft. below land surface Date 3-25-68		
A sesian pressure lbs. per square inch Date		
(9) WELL TESTS: Drawdown is amount water level is lowered below static level		
lowered below static level		
Was a pump test made? Yes No If yes, by whom? Driller	Work started 3-25 19 68 Completed 3-2	25 ¹⁹ 68
gal./min. with 6 ft. drawdown after 1 hrs.	Date well drilling machine moved off of well 3-2	
" " "	Drilling Machine Operator's Certification:	
	This well was constructed under my direct supervis	sion. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true knowledge and belief	to my best
Artesian flow g.p.m. Date	(1 1 1 6 1 1 1 1 2 2 2 2 2 2 2 2 2 2 2 2	E 10.69
Temperature of water Was a chemical analysis made? ☐ Yes 🙀 No	[Signed] Grilling Machine Operator) Date 3-2	J, 19.QQ
(10) CONSTRUCTION: /Bentonite	Drilling Machine Operator's License No386	
Well seal—Material used		-
Depth of seal ft.	Water Well Contractor's Certification:	
Diameter of well bore to bottom of seal in.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME Pitcher Pump & Drilling Co.	
Were any loose strata cemented off? Yes No Depth		
Was a drive shoe used? ☐ Yes ☑ No	(Person, firm or corporation) (Type or print)	
Did any strata contain unusable water? Yes No	Address 255 W. 5th/ Junction City. Oregon	
Type of water? depth of strata	- (1) 4.1	
Method of sealing strata off	— [Signed]	
Was well gravel packed? [] Yes [No Size of gravel:		.c. 40
Createl placed from ft to ft	Contractor's License No. 494 Date 3-2.5	, 19.00