NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 16 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

LANE
C185
G-5458

State Well No. 15/4W-21baa
State Permit No.

(1) OWNER:
Name VIOLA STRETCH
Address R-1- Box 226, HARRISBURG ORE

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☒
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☒ Welded ☐
5" Diam. from 0 ft. to 26 ft. Gage .258
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Acetylene
Size of perforations 1/4 in. by 4 in.
32 perforations from 21 ft. to 26 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 14 ft. below land surface Date 5/16/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 300 gal./min. with 6 ft. drawdown after 2 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used Bentonite
Depth of seal 6 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County LANE Driller's well number
¼ ¼ Section 21 T. 15S R. 4W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing
Depth drilled 26 ft. Depth of completed well 26 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil & Brown clay	0	11	
packed sand & gravel	11	20	
Coarse sand & gravel, Water bearing	20	26	14

Work started 5/16 1969 Completed 5/16 1969
Date well drilling machine moved off of well 5/16 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] O. B. Nye (Drilling Machine Operator) Date 5/16, 1969
Drilling Machine Operator's License No. -211-

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME O. B. NYE (Person, firm or corporation) (Type or print)
Address JUNCTION CITY ORE 97448
[Signed] O. B. Nye (Water Well Contractor)
Contractor's License No. 151- Date 5/16, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)