NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 8 1966 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

LANE 6230

State Well No. 15/4W-29d/6

G5092 State Permit No. .....

(1) OWNER:
Name JENS REERSLEV
Address 220 18th Ave E
JUNCTION CITY ORE

(2) LOCATION OF WELL:
County LANE Driller's well number
¼ ¼ Section 29 T. 15S R. 4W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☒
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☒ Welded ☐
5" Diam. from 0 ft. to 28 ft. Gage 1250
..." Diam. from ... ft. to ... ft. Gage ...
..." Diam. from ... ft. to ... ft. Gage ...

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Acetylene
Size of perforations 1/4 in. by 4 in.
42 perforations from 23 ft. to 28 ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name ...
Type ... Model No. ...
Diam. ... Slot size ... Set from ... ft. to ... ft.
Diam. ... Slot size ... Set from ... ft. to ... ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 6 ft. Was a packer used? ...
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth ...
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel: ...
Gravel placed from ... ft. to ... ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 10 ft. below land surface Date 6/4/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 300 gal./min. with 7 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing ...
Depth drilled 28 ft. Depth of completed well 28 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil + Brown clay	0	13
packed sand + gravel	13	21
Water Bearing sand	21	28
& gravel, coarse		

Work started 6/4 1966 Completed 6/4 1966
Date well drilling machine moved off of well 6/4 1966

(13) PUMP:
Manufacturer's Name Jacuzzi
Type: Cent H.P. 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O. B. NYE
(Person, firm or corporation) (Type or print)
Address JUNCTION CITY ORE
Drilling Machine Operator's License No. 211
[Signed] O. B. Nye
(Water Well Contractor)
Contractor's License No. 151 Date 6/4, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)

well #5