NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

LANE	15/1111 2
6270 State Well No.	15/4W-3000

The original and first copy of this report are to be of this report are to be filled with the fill 3 1 1969 STATE OF OREGON (Please type or print) within 30 days from the fill ELLE OF COREGON (Please type or print) of well completion. CALEM OREGON

6210	State	weii No.
35654	State	Permit No

1) OWNER: (11) LOCATION OF WELL:					
Name Clarry Ottesen	County Lane Driller's well number				
Address 1040 Gilman Dr., Colma, California	14 14 Section 30 T. 155	R. 4	łW	W.M.	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivisio	n corner			
New Well Deepening Reconditioning Abandon If abandonment, describe material and procedure in Item 12.			 		
	-				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well 1	oelow cas	ing(<u> </u>	
Cable	Depth drilled 23-6 ft. Depth of compl	eted well	23_6	ft.	
Dug Bored Irrigation Test Well Other	Formation: Describe color, texture, grain size				
CASING INSTALLED: Threaded □ Welded X	and show thickness and nature of each stratu			_	
5 7 Diam. from 0 ft. to _23_6 ft. Gage280	with at least one entry for each change of form in position of Static Water Level as drilling pro				
ft. to ft. Gage	MATERIAL .	From	То	SWL	
ft. to ft. Gage	soil & sand	0	10		
PERFORATIONS: Perforated? [X Yes] No	sand & gravels tight	10	14		
,	sand & gravel loose	14	23-6	61	
Size of perforations 3/8 in. by 6 in.					
42 perforations from23 ft. to18 ft.					
perforations from ft. to ft.	4				
perforations from					
perforations fromft. toft.					
perforations fromft. toft.					
(7) SCREENS: Well screen installed? ☐ Yes ☑ No			-		
Manufacturer's Name					
Type Model No.		1		······································	
Diam Slot size Set from ft. to ft.	·	 		-	
Diam. Slot size Set from ft. to ft.					
(8) WATER LEVEL: Completed well.				 -	
Static level 6 ft. below land surface Date 7_1_60		·			
Sian pressure lbs. per square inch Date					
(9) WELL TESTS: Drawdown is amount water level is				• .	
lowered below static level		-			
Was a pump test made? ✓ Yes No If yes, by whom? driller	Work started 7-1 1969 Complet	ed 7-1		19 69	
Yield: 400 gal./min. with 10 ft. drawdown after 1 hrs.	Date well drilling machine moved off of well	7-1		19 69	
" " "	x x - x				
" " "	Drilling Machine Operator's Certification:	. <u>.</u>	·		
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my drials used and information reported above				
Artesian flow g.p.m. Date	knowledge and belief.	مذ	./- ^		
Temperature of water Was a chemical analysis made? Yes No	[Signed] (Drifting Machine Operator)	Date	129	, 196.7	
(10) CONSTRUCTION:	Drilling Machine Operator's License No.	386	•	•	
Well seal—Material usedbentonite	Brining Machine Operator's Electise 110.				
Depth of seal ft.	Water Well Contractor's Certification:				
Diameter of well bore to bottom of seal10 in.	This well was drilled under my jurisd true to the best of my knowledge and beli		nd this r	eport is	
Were any loose strata cemented off? Tyes XNo Depth				*	
Was a drive shoe used? ☐ Yes ☒ No	NAME Pitcher Pump & Drillin	E (Typ	e or print)		
Did any strata contain unusable water? Yes No	Address 255 W., 5th. Junction	/Oitv	Oreg	on	
Type of water? depth of strata		, 		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
Method of sealing strata off	[Signed] Carl Get Coll	4	••••		
Was well gravel packed? ☐ Yes X☐ No Size of gravel:	(Water Well Contra	tor)	6	, .A.	
Gravel placed from ft. to ft.	Contractor's License No. 494 Date	112		1962	