NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REH STATE OF OREGON

(Please type or priSTATE ENGINEER

(Do not write above this lightly Original States Permit No. ...

G-4766

(1) OWNER:	(11) LOCATION OF WELL:	
Name Mr. Clarry Ottosen	County Lane Driller's well number	
Address 132 Ottosen Lane, Junction City, Oregon	14 14 Section 30 T. 15 R. 4W W.M.	
	Bearing and distance from section or subdivision	corner
(2) TYPE OF WORK (check):		
New Well 🗓 Deepening 🗌 Reconditioning 🗌 Abandon 🔲	\$	
If abandonment, describe material and procedure in Item 12.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well bel	ow casing O
Rotary Driven K Domestic Industrial Municipal Domestic Municipal	Depth drilled 32 ft. Depth of complete	06.6
Dug ☐ Bored ☐ Irrigation	Formation: Describe color, texture, grain size an	
CASING INSTALLED: Threaded Welded	and show thickness and nature of each stratum	and aquifer penetrated,
5" Diam. from	with at least one entry for each change of format in position of Static Water Level as drilling proce	-
" Diam. fromft. toft. Gage		From To SWL
" Diam, from ft. Gage ft. Gage	soil	0 6
DEDEOD ATIONS.	sand & gravel	6 12
PERFORATIONS: Perforated? M Yes No.	sand	12 16
Type of perforator used tor ch	sand & gravels	16 26 13'
Size of perforations 27 - In. by Im.	sand & gravels w/clay	26 32 131
42 perforations from		
perforations from ft. to ft.		
perforations fromft. toft.		
perforations from		
perforations from ft, to ft.	L.	
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	A	
Manufacturer's Name		
Type Model No.		
Diam. Slot size ft. to ft.		
Diam. Slot size Set from ft. to ft. to ft.		
(8) WATER LEVEL: Completed well.		
Static level 13 ft. below land surface Date 8/2/68		
A lian pressure lbs. per square inch Date		
(9) WELL TESTS: Drawdown is amount water level is	· · · · · · · · · · · · · · · · · · ·	
lowered below static level		
Was a pump test made? Yes No If yes, by whom? Driller	Work started 9_2 1968 Completed	1 9-2 1968
vield: 225 gal./min. with 7 ft. drawdown after 1 hrs.	Date well drilling machine moved off of well	9- 7 19 68
" "		<u> </u>
и и и	Drilling Machine Operator's Certification:	·
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direction reported above	
Artesian flow g.p.m. Date	knowledge and belief	0.10
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No	[Signed] And Geller I	Date 9-10 , 1968.
(10) CONSTRUCTION:	(Drīlling Machine Operātor)	-04
Well seal—Material used Bentonite	Drilling Machine Operator's License No. 386	
Depth of seal 6 ft.	Water Well Contractor's Certification:	
Diameter of well bore to bottom of seal 8 in.	This well was drilled under my jurisdic	tion and this report is
Were any loose strata cemented off? Yes No Depth	true to the best of my knowledge and belief	•
Was a drive shoe used? Tyes Tho	NAME Pitcher Pump & Drilling Co. (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water? Yes Y No		
Type of water? depth of strata	Address 255 West 5th St. Junction City. Oregon	
Method of sealing strata off	ssimula (AAN (to)	1.
Was well gravel packed? ☐ Yes ☒ No Size of gravel:	[Signed] (Water Well Contracto	or)
Course placed from	Contractor's License No. 494 Date C	19 68