

LANE  
6400

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 15/4W-32 AB

State Permit No.

RECEIVED  
SEP 13 1966

(1) OWNER:

Name City of Junction City  
Address Junction City ORE

(2) LOCATION OF WELL:

County LANE Driller's well number  
1/4 Section T. R. W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 30 ft. Gage 250  
" Diam. from " ft. to " ft. Gage  
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used Acetylene  
Size of perforations 1/4 in. by 4 in.  
49 perforations from 2.7 ft. to 30 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Model No.  
Slot size Set from " ft. to " ft.  
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite  
Depth of seal 6 ft. Was a packer used?  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from " ft. to " ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 16 ft. below land surface Date 8/13/66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 100 gal./min. with 6 ft. drawdown after 2 hrs.

Ballor test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 54 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 30 ft. Depth of completed well 30 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil + Brown clay	0	12
packed sand + gravel	12	21
Water bearing sand + gravel	21	24
yellow clay	24	26
packed sand.	26	27
yellow clay.	27	30

Work started 8/11 1966 Completed 8/13 1966

Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O. B. Nyle (Type or print)

Address Junction City ORE

Drilling Machine Operator's License No. -211.

[Signed] O. B. Nyle (Water Well Contractor)

Contractor's License No. 151 Date 8/13 1966

---

The north 44 feet of the east  
10 chains of Lot 16 & the west 5  
chains of Lot 15 of Miellet's Plat,  
as platted & recorded at Page 69,  
Volume 2, Lane County Oregon Plat  
Records, Lane County, Oregon.

Well For City of Junction City  
Junction City, Ore