NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

ANEWATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON MAY 141974 State Well No. 155

(Please type or print) STATE ENGINEER Permit No. ... (Do not write above this lingALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:	
Name Don Bodtker	County Tane Driller's well nu	7 1 1 2 2
Address 750 Love Lake Rd.	¼ ¼ Section 33 т. 15S	the marks of the following of the property of the particular of th
Junction City, Oregon	Bearing and distance from section or subdivisio	n corner
(2) TYPE OF WORK (check):		
New Well 🚨 Deepening 🗌 Reconditioning 🗍 Abandon 🗌		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	ell.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	22 ft.
Rotary Driven Domestic Industrial Municipal D	Static level 9 ft. below land st	urface. Date 4/28/74
Cable A Jetted	Artesian pressure Ibs. per square	「コープラー」 かい Text identification Applies
Dug Bored I Irrigation Test well P Other	Artesian pressure	
5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well b	elow casing 12
12 " Diam. from 0 ft. to 40 ft. Gage 250	Depth drilled 3970 ft. Depth of comple	eted well 39 ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size a	
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratur	n and aquiter penetrated,
	with at least one entry for each change of format position of Static Water Level and indicate prin	ion. Report each change in
6) PERFORATIONS: Perforated? X Yes I No.		
Type of perforator used Torch Cut	MATERIAL	
Size of perforations $\frac{1}{2}$ in. by $\frac{3}{2}$ in.	Topsoil	0 1
120 perforations from 24 ft. to 36 ft.	Brown clay	1 6
perforations fromft, toft.	Brown clay & gravel	6 17
perforations from ft. to ft.	Sand & gravel	17 39
periorations from ,	位置	
(7) SCREENS: Well screen installed? Yes X No		
Manufacturer's Name		
Type Model No.		
Diam. Slot size Set from ft. to ft.		
Diam Slot size Set from ft. to ft.		
	A	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? ☐ Yes ②I No If yes, by whom?		
Yield: gal./min. with ft. drawdown after hrs.		
" " "		1
m to a with sime could fluctuate "		
"Tested with air: could fluctuate " Bank test 700+ gal/min. with 12 ft. drawdown after 1 hrs.		
Ball-X test 700+ gal./min. with 12 ft. drawdown after 1 hrs.		+
Artesian flow g.p.m.	106/74	1/29/7/ 19
emperature of water Depth artesian flow encountered ft.	Work started 4/26/74 19 Comple	" · · · · · · · · · · · · · · · · · · ·
(9) CONSTRUCTION:	Date well drilling machine moved off of well	
Well seal—Material usedCement	Drilling Machine Operator's Certification	dinact supervision
Well sealed from land surface to	Drilling Machine Operators Certification This well was constructed under not Materials used and internation reported best knowledge and best from the construction of	i above are true to my
Diameter of well bore to bottom of seal16in.		
Diameter of well have below seal		Bate 5/8/74, 19
Number of sacks of cement used in well seal6sacks	Drilling Machine Operator's License No	
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No.	
Brand name of bentonite	Water Well Contractor's Certification:	4
Number of pounds of bentonite per 100 gallons	This well was drilled under my juris	diction and this report is
of waterlbs./100 gals.	true to the best of my knowledge and b	elief.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.	Name Corvallis Drilling Co.	Inc.
Did any strata contain unusable water? Yes I No		(Type or print)
Type of water? depth of strata	Address 3440 SW 3rd St. Corva	
Method of sealing strata off	Issued Marine A Kan	sieri
	[Signed] (Water Well Con	ntractor.
Was word Branch and State of the State of th	Contractor's License No. 560 Date	5/8/74, 19
Gravel placed from ft. to ft.	1 0011010101 1 11100110	GT-45650 110