## NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

filed with the

WATER WELL REPORT MAY 2 1968

STATE OF OREGON TATE ENGINEERS. / (Please type or print) SALEM. OREGON (Do not write above this line) SALEM. State Permit No. ....

G-4357

(1) OWNER:	(11) LOCATION OF WELL:
Name Mr. Hans Rasmussen	County Lane Driller's well number
Address 751 Dane Lane, Junction City, Oregon	
(9) MVDE OF WORK (-LL).	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well Deepening Reconditioning Abandon   Keepening Reconditioning Abandon	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casingO
Cable	Depth drilled 29 ft. Depth of completed well 29 ft.
Dug   Bored   Irrigation T Test Well   Other	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded □ Welded ₩	and show thickness and nature of each stratum and aquifer penetrated,
5 " Diam. from 0 ft. to 29 ft. Gage •285	with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.
	MATERIAL From To SWL
"Diam. fromft. toft. Gage	soil & sand 0 12
PERFORATIONS: Perforated? For Yes     No.	sand & gravels 12 18
Type of perforator used torch	sand 18 24
	sand & gravels 24 29 8181
Size of perforations 3/8 in. by 6 in.  34 perforations from 27 ft. to 23.6 ft.	
-	
perforations from ft. to ft.	-
perforations fromft. toft.	
perforations fromft. toft.	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	
Manufacturer's Name	- to-re-
TypeModel No DiamSlot sizeSet fromft. toft.	
Diam. Slot size Set from ft. to ft.  Diam. Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
Static level 8.8 ft. below land surface Date 4_8_68	
Art. sian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is	
lowered below static level   Was a pump test made?    Yes   No   If yes, by whom?   Driller	
750 5	Work started 4-8 1968 Completed 4-8 1968
	Date well drilling machine moved off of well 4-8 1968
	and the second of the second o
	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
Temperature of water Was a chemical analysis made?  Wes Was a Chemical analysis made?  Wes Was a Chemical analysis made?	[Signed] (Drilling Machine Operator) Date 4-8 , 19.68.
(10) CONSTRUCTION:	Drilling Machine Operator's License No386
Well seal—Material used Bentonite	Drining Machine Operator's Dicense 140.
Depth of sealft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal in.	This well was drilled under my jurisdiction and this report is
Were any loose strata cemented off?   Yes  No Depth	true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☑ No	NAME Pitcher Pump & Drilling Co. (Person, firm or corporation) (Type or print)
Did any strata contain unusable water?   Yes   No	Address 255 West 5th, Jungtion City, Ore. 97448
Type of water? depth of strata	10 11 11 1
Method of sealing strata off	[Signed] Call Gallet
Was well gravel packed? ☐ Yes 🗶 No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 494 Date 4-8 , 19.68