LANE
6462

RECEIVED
JUN 1 1966
STATE ENGINEER
SALEM OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 15/4W-34

State Permit No.

(1) OWNER:
Name BEN JENSEN
Address 300 WILLAMETTE DRIVE JUNCTION CITY ORE

(2) LOCATION OF WELL:
County LANE Driller's well number
¼ NW ¼ Section 34 T. 15S R. 4W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☒
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☒ Welded ☐
5" Diam. from 0 ft. to 26 ft. Gage .258
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No
Type of perforator used Acetylene
Size of perforations 1/4 in. by 4 in.
36 perforations from 22 ft. to 26 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 6 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 8 ft. below land surface Date 5/26/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: 300 gal./min. with 5 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing –
Depth drilled 26 ft. Depth of completed well 26 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil & Brown Sand	0	11
Packed Sand & gravel	11	19
Water bearing Sand & Course gravel	19	26

Work started 5/26 1966 Completed 5/26 1966
Date well drilling machine moved off of well 5/27 1966

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME O. B. NYE (Person, firm or corporation) (Type or print)
Address JUNCTION CITY ORE
Drilling Machine Operator's License No. 211
[Signed] O. B. Nye (Water Well Contractor)
Contractor's License No. 151 Date 5/27, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)