## STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

NOV 61984

(for official use only)

	(101 dilloid doc dilly)
(1) OWNER:	(10) LOCATION OF WELL by legal description:
Name Bob Meltebeke - Paradise Homes #9	County Lane NE NW 4 of Section 25
Address 3324 Regent	Township 16S Range 3W
City Eugene, State Oregon	Par(Counthip is North or South) (Range is East or West)
(2) TYPE OF WORK (check):	Tak Hot 3 Lot 1 Block Subdivision 1st Addition MAILING ADDRESS OF WELL (or nearest address) Country View Est.
	MAILING ADDRESS OF WELL (or nearest address) Coburg, Oregon
New Well K Deepening Reconditioning Abandon C	ODDUIG, OTEGOR
If abandonment, describe material and procedure in Item 12.	(44) 774 7777 7777
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLETED WELL:
Rotary Air Driven Domestic Industrial Municipal Municipal Thermal;	Depth at which water was first found 60 ft.
Rotary Mud Dug Irrigation Withdrawal Reinjection	Static level 20 ft, below land surface. Date 10/19
Other:  Bored Piezometric Grounding Test	Artesian pressure lbs. per square inch. Date
	(12) WELL LOG: Diameter of well below casing 6" 200 ft. Depth of completed well 200 ft.
(5) CASING INSTALLED: Steel Heating Threaded Heating Welded H	Depth drilled 200 ft. Depth of completed well 200 ft.
8 +1 39 250	Formation: Describe color, texture, grain size and structure of materials; and show thickness
It. to	and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal
Diam. fromft. Gauge	water-bearing strata.
LINER INSTALLED: Steel  Plastic  Welded  Welded	MATERIAL From To SWL
	Top Soil 0 3
(6) PERFORATIONS: Perforated? □ Yes □ No	Brown Clay 3 20
Size of perforations in. by in.	Blue Clay 20 30
perforations from ft. to ft.	Blue Shale 30 200 20
perforations from	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed?  \[ \subseteq \text{Yes}  \text{No} \]	
Manufacturer's Name	
Type Model No.	
Diam. Set from ft. to ft.	
Diam Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes XXNo If yes, by whom?	
d: gal./min. with ft. drawdown after hrs.	
Air test 60 gal/min with drill stars at 175 ft 1 has	
gan/mm. with drin stem at 2 / 3 it. 1 mrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
aperature of water 52° Depth artesian flow encountered ft.	Date work started 10/15/84 (completed 10/19/84
(9) CONSTRUCTION: Special standards: Yes \(\sigma\) No \(\sigma\)	Just work stated 1 7 /completed 2 9 / 2 5 / 9 /
Well seal—Material usedCement	Date well drilling machine moved off of well 10/20/ 1984
Well sealed from land surface to	(unbonded) Water Well Constructor Certification (if applicable):
Diameter of well bore to bottom of seal12in.	This well was constructed under my direct supervision. Materials used and
Diameter of well bore below seal	information reported above are true to my best knowledge and belief.
Amount of sealing material	[Signed]
How was cement grout placed?	
The second process of the second seco	(bonded) Water Well Constructor Certification:
	Bond U0-307869 Issued by: United Pacific (Surety Company Name)
Was pump installed? Type	On behalf of Carter's Drilling & Pump Service
Was a drive shoe used?  Yes  No Plugs	(type or print name of Water Well Constructor)
Did any strata contain unusable water?  Yes No	This well was drilled under my jurisdiction and this report is true to the
Type of Water? depth of strata	best of my knowledge and belief:
Method of sealing strata off	
	(Signed) (Water Well Constructor)
Was well gravel packed? Yes KNo Size of gravel:	(Dated) 10/19/84
NOTICE TO WATER WELL CONSTRUCTOR	WATER RECOURSE DEDARMINER