

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT RECEIVED

165/2W-34

FEB 17 1976

STATE OF OREGON

JAN 29 1976

State Well No.

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

WATER RESOURCES DEPT. SALEM, OREGON

(Please type or print)

Do not write above this line

State Permit No.

SALEM, OREGON

(10) LOCATION OF WELL:

LANE 7286

(1) OWNER:

Name Conner Kessler
Address 91130 Donna Road Springfield, Oregon 97477

County Lane Driller's well number
1/4 Section #6 T. 34 R. 2-W W.M.
Bearing and distance from section or subdivision corner 125 ft West of Donna Road + 100 ft. North of Hill Road.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(11) WATER LEVEL: Completed well. 71-ft-Good

Depth at which water was first found 14 ft. (Scale Out) ft.
Static level 7 ft. below land surface. Date Jan-16
Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary [] Driven [] Domestic [X] Industrial [] Municipal []
Cable [] Jelled [] Irrigation [] Test Well [] Other []
Bored []

(12) WELL LOG: Diameter of well below casing 6"

Depth drilled 98 ft. Depth of completed well 98 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Sandy Soil (Brown), Boulders with clay (Brown), Claystone (Blue), Boulders (Blue) (Hard), Sandstone (Blue-Black), Sandstone (Gray+white).

CASING INSTALLED:

6" Diam. from 0 ft. to 48 ft. Gage 250
Threaded [] Welded [X]

PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Contractor
Yield: 5 gal./min. with 33 ft. drawdown after 4 hrs.
10 " 61 " 2 "

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 28 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 18 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

Work started Dec. 29 1975 Completed Jan-17 1976

Date well drilling machine moved off of well Jan-23-1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harold White Date 1-28, 1976 (Drilling Machine Operator)

Drilling Machine Operator's License No. 1040

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Lee Well Drilling & Pump Service (Person, firm or corporation) (Type or print)

Address 90969 Hill Road Springfield

[Signed] Kurt E. Lee (Water Well Contractor)

Contractor's License No. 613 Date 1-28-1976