

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the
 WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)
RECEIVED (Do not write above this line)

Jane
737

State Well No. 165/3W-39
 State Permit No. _____

SEP 26 1978

(1) OWNER:
 Name Bob Meltebeke WATER RESOURCES DEPT
 Address 3324 Regent SALEM OREGON
Eugene, OR 97401

(2) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Cable Dug
 Driven Jetted Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:
 Threaded Welded
 6" Diam. from 0 ft. to 55 ft. Gage 250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

PERFORATIONS:
 Perforated? Yes No.
 Type of perforator used torch
 Size of perforations $\frac{1}{4}$ in. by 6 in.
 84 perforations from 35 ft. to 55 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " "
 Air Tested: Could fluctuate " "
~~Water Test~~ 35 gal./min. with 40 ft. drawdown after 1 hrs.
 Artesian flow _____ g.p.m.
 Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used cement
 Well sealed from land surface to 20 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Number of sacks of cement used in well seal 5 sacks
 How was cement grout placed? poured

 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: 3/8 -
 Gravel placed from 20 ft. to 55 ft.

(10) LOCATION OF WELL:
 County Lane Driller's well number _____
 1/4 Section 34 T. 16 S R. 3 W W.M.
 Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
 Depth at which water was first found 40 ft.
 Static level 15 ft. below land surface. Date 8-21-78
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 6"
 Depth drilled 55 ft. Depth of completed well 55 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Brown Clay	1	12	
Brn. Clay/Med. Bldrs/Med			
Gravel	12	45	
Medium Gravel & Coarse			
Sand	45	55	

Work started 8-21 1978 Completed 8-21 1978
 Date well drilling machine moved off of well 8-22 1978

Drilling Machine Operator's Certification:
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] H. A. Kinman Date 8-22 1978
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 1160

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name Casey Jones Well Drilling Co., Inc.
 (Person, firm or corporation) (Type or print)
 Address 37115 Immigrant Road - Pleasant Hill, OR
 [Signed] Casey Jones
 (Water Well Contractor)
 Contractor's License No. 559 Date 8-24 1978