STATE OF OREGON

WATER WELL REPORT

(as required by ORS 537.765)

RECEIVED NOV 61984

PLEASE WATE OF PRINTING INKES DEPT (for official use only)

(1) OWNER: Name Bob Meltebeke- Paradise Homes #5	(10) LOCATION OF WELL by legal description:	
Address 3324 Regent	County	Sectionof
City Eugene, State Oregon	Township Range	\$3/1\d
State C	Tax Lot 100 Lot 12 Block Subdivigion	ange is East or West) LST Addition
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address) Coburg,	-
New Well $\ \ \ \ \ \ \ \ \ \ \ \ \ $	Coburg,	Oregon
If abandonment, describe material and procedure in Item 12.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLETE	D WELL:
Rotary Air 🔀 Driven 🗌 Domestic 🗆 Industrial 🗋 Municipal 💢	Depth at which water was first found 130	ft.
Rotary Mud Dug Irrigation Withdrawal Reinjection	Static level ft. below lar	nd surface, Date 10/4/8
Other:	Artesian pressure lbs. per sq	uare inch. Date
Bored Piezometric Grounding Test	- (12) WELL LOG: 5 Diameter of well below casing 6"	
8 Diam. from +1 ft. to 99 Gauge 250 6 Diam. from ft. to 6 Gauge 250	Depth drilled 500 ft. Depth of completed well 500 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.	
LINER INSTALLED: Steel	MATERIAL	From To SWL
	Top Soil	
	Brown Clay	3 26
(6) PERFORATIONS: Perforated? □XYes □ No Size of perforations 1/4 in. by 2 in.	Brown Clay & Boulders	
	Brown Shale	45 70
periorations from	Loose Red Shale - Clay	70 87
perforations from ft. to ft.	Lt. Grey Shale	87 500
perforations from ft. to ft.		
(7) SCREENS: Well screen installed? ☐ Yes ☐ No Manufacturer's Name		
(8) WELL TESTS: Drawdown is amount water level is lowered		
below static level		
Was a pump test made? Yes No If yes, by whom?		
d: gal./min. with ft. drawdown after hrs.		
" " " " "		
Air test 12 gal./min. with drill stem at 150_{ft} , 1 hrs.		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m. Superature of water 52 Donth ortogical flow arrespondent of the control of		
nperature of water 52 Depth artesian flow encountered ft.	Date work started 9/5/84 (completed	10/4/84
(9) CONSTRUCTION: Special standards: Yes \(\text{No} \) \(\text{No} \)		101/1
Well seal—Material usedCement	Date well drilling machine moved off of well	
Well sealed from land surface to ft.	(unbonded) Water Well Constructor Certification	
Diameter of well bore to bottom of seal 12 in.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.	
Diameter of well bore below seal		
Amount of sealing material sacks 🗵 pounds 🗆	[Signed] Dat	ie, 19
How was cement grout placed? Method "C"	(bonded) Water Well Constructor Certification:	
	Bond U0-307869 Issued by: United Pacific (Surety Company Name)	
Was pump installed?		
Was a drive shoe used? Yes X No Plugs Size: location ft.	On behalf of Carter's Drilling & Pump Service (type or print name of Water Well Constructor)	
ords a drive since used: I fee A No Plugs Size: location	This well was drilled under my jurisdiction and this report is true to the	
Type of Water? depth of strata	best of my knowledge and belief:	uns report is true to the
Method of sealing strata off	1	/ / /
	(Signed)	
Fravel placed fromft. toft.	(Dated)	10/4/84
AVI		