NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER WELL REPORT

LANE

Stat	e Well 1	No	165	13W-	17
			14	1	

WATER RESOURCES DEPARTMENT C SALEM, OREGON 97810 Within 30 days from the date V STATE OF OREGON (Please type or print)

AUG 16 197900 not write above this line) of well completion.

State Permit No.

(1) OWNER: WATER RESOURCES DEPT	(10) TOCAMION OF WITH			
Name Bohemia, Inc. SALEM, OREGON	(10) LOCATION OF WELL: County Lane Driller's well number 605-135			
Address 2280 Oakmont Way	Difficial Well Hamber 0 = 00			
Eugene, Oregon 97401				
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner Tax Lot No = 201			
New Well XX Deepening □ Reconditioning □ Abandon □	1 dx Lot No. 201			
If abandonment, describe material and procedure in Item 12.	(11) THE APPEND A PROPERTY OF THE PARTY OF			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.			
Rotary Driven D	Depth at which water was first found 11 ft			
Due of Daniel II	Static level 11'6" ft. below land surface. Date 7/13/7			
	Artesian pressure lbs. per square inch. Date			
CASING INSTALLED: Threaded Welded XX	(12) WELL LOG: Diameter of well below easing 8"			
"Diam. from +1 ft. to 40 ft. Gage = 250	Diameter of well below casing			
"Diam. fromft. toft. Gage				
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials and show thickness and nature of each stratum and aquifer penetrated			
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata			
Type of perforator used				
Ni P P P P P P P	MATERIAL From To SWL			
size of perforations in, by in. perforations from ft. to ft.	Clay, brown-gray 6 12			
perforations from ft. to ft.	Gravel, med./w clay 12 28 11'6			
perforations from ft. to ft.	Gravel, med: cobbles 28 28 6"			
	Gravel, fine w/silt and			
(7) SCREENS: Well screen installed? Yes I No Monufactureric Name Young	clay 28'6" 34			
Manufacturer's Name 301113011 Type Stainless Steel Telemodel No. Diam. Slot size *020 Set from 40 ft. to 55 ft.	Gravel, fine water bearing 34 39			
Type Ocal III ess Oce 1 Tel Model No.	Sandy clay 39 40			
Diam. Slot size *020 Set from 40 ft. to 55 ft. Diam. Slot size *025 Set from 55 ft. to ft.	Sand w/clay waterbearing 40 43 12'9			
Diani	Sand, brown, fine WB 43 47			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Gravel, med w/silt and			
Was a pump test made? XYes \(\subseteq \) No If yes, by whom?	Clay 47 54 54 6"			
Viola, 1/0 May 8	Clay 54 54 6" Sand w/clay 54'6" 55			
110 " 23'6" " "	Sand, clean waterbearing 55 57 6"			
" 80 " 19'6" " "	Gravel, fine w/sand WB 57'6" 60			
And the second s	Sand, med fine, ptly cem 60 63			
and the state of t	Clay 63 97 19			
Artesian flow g.p.m.	Gravel, fine WB 97 116 135			
perature of water Depth artesian flow encountered ft.	Work started 6/26/ 1979 Completed July 16 1979			
(9) CONSTRUCTION:	Date well drilling machine moved off of well July 16 1979			
Well seal-Material used Portland Cement Grout	Drilling Machine Operator's Certification:			
Well sealed from land surface to	This well was constructed under my direct supervision.			
Diameter of well bore to bottom of seal 12 in.	Materials used and information reported above are true to my best knowledge and belief			
Diameter of well bore below seal in.	[Signed] Date 7/16/ 1979			
Number of sacks of cement used in well seal 12 sacks	(Drilling Machine Operator)			
How was cement grout placed? Pumped	Drilling Machine Operator's License No. 931			
	Water Wall Contractoris Contistant			
	Water Well Contractor's Certification:			
Wilson a delice of the state of	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used? Yes No Plugs Size: location ft.	Name Hoeck Well Drilling			
Did any strata contain unusable water? Type of water?	(Person, firm or corporation) (Type or print) D			
Type of water? depth of strata	Address P. O. Box 1377, Lugerie, OK 97440			
Method of sealing strata off	[Signed] John Hola C			
Was well gravel packed? ☐ Yes XXNo Size of gravel:	(Water Well Contractor)			
Gravel placed from ft. to ft	Contractor's License No. 605 Date July 16 1979			