NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

7394

State Well No. 165 3w -/2

to the second se	
(1) OWNER:	(10) LOCATION OF WELL:
Name Bohemia, Inc.	county Lane Driller's well number 605-135
Address 2280 Oakmont Way	34 14 Section 17 T16 S *R. 3 W * W.M.
Eugene, Oregon 97401	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Tax Lot 201
New Well □ Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.
Rotary Driven Domestic Industrial XX Municipal	Static level ft. below land surface. Date
1 Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing
" Diam. from ft. to ft. Gage	Depth drilled ft. Depth of completed well ft.
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials;
(6) PERFORATIONS: Perforated? Yes No.	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL, From To SWL
Size of perforations in. by in.	Treat with Acid.
perforations from ft. to ft.	
perforations from ft. to ft.	Remove existing screen.
perforations from ft. to ft.	D-los of its
(7) SCREENS: Well screen installed? ★ Yes □ No	Replace stainless steel
Manufacturer's Name Johnson	screen*
Type Stainless Steel Telescope	Redevelop well and test
Diam. 8" Slot size *015 Set from 38'4" xx to 54'8" *	pump *
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	OPAPILIPA -
a pump test made? XYes No If yes, by whom? Driller	- NEULIVED
Yield: 120 gal./min. with 20 ft, drawdown after 2-34hrs.	OCT 2/1 1979
" " " " " " " "	
# # # # # # # # # # # # # # # # # # #	WAILR RESOURCES DEPT
Poler test gal./min. with ft. drawdown after hrs.	SALEM, OREGON
esian flow g.p.m.	
Temperature of water Depth artesian flow encounteredft.	Work started 10/9 1979 Completed 10/17 1979
(9) CONSTRUCTION:	
Well seal—Material used Seal not disturbed. Well sealed from land surface to	Drilling Machine Operator's Certification: This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal in.	Materials used and information reported above are true to my
Diameter of well bore below sealin.	best knowledge and belief. [Signed] Date 10/22/, 1979
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)
How was cement grout placed?	Drilling Machine Operator's License No. 931
	Water Well Contractor's Cartification
	Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	Name Hoeck Well Drilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address P = 0 , Box 1577, Eugene, OR 97440
Method of sealing strata off	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed fromft. toft.	Contractor's License No. 605 Date Oct * 22