

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
JAN 3 WATER WELL REPORT LANE 7456
STATE OF OREGON
(Please type or print)
G-4283

State Well No. 14/3W-29 A
State Permit No.

(1) OWNER: City of Colberg
Name WATER WELL SEARCH
Address RTA Box 447
EURENE Colberg, Oregon

(2) LOCATION OF WELL:
County LANE Driller's well number
1/4 1/4 Section 29 T. 16 R. 3 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 201.4 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No
Type of perforator used
Size of perforations 1/2 in. by 3 in.
472 perforations from 3.5 ft. to 94 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
in. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal BENTONITE
Depth of seal 30 ft. Was a packer used?
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 5' 4" ft. below land surface Date 11-4-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: 300 gal./min. with 59 ft. drawdown after 5 hrs.
" " " "
" " " "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 12
Depth drilled 201 ft. Depth of completed well 200 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	4
GRAVEL SEALED WITH BENTONITE	4	30
SAND & GRAVEL	30	33
SAND & GRAVEL BROWN SAND	33	35
SAND & GRAVEL	35	50
PAKED 206PM @ 39'		
CLAY SAND & GRAVEL	50	51
SAND & GRAVEL CEMENTED	51	66
SAND & SMALL GRAVEL	66	94
SAND & CLAY	94	106
TAN CLAY	106	120
BLUE CLAY	120	166
BLUE CLAY WITH BROW CLAY	166	201

Work started 10-8 1963 Completed 11-5 1963
Date well drilling machine moved off of well 11-5 1963

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MARK CHRISTENSEN
(Person, firm or corporation) (Type or print)

Address 3550 W 18th EURENE

Drilling Machine Operator's License No. 97

[Signed] Mark W Christensen
(Water Well Contractor)

Contractor's License No. 97 Date 11-10 1963