

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

LANE
7482

WATER WELL REPORT

STATE OF OREGON
(Please type or print)
(Do not write above this line)

See GR-1039
GR-1039
RECEIVED
FEB 28 1968
STATE ENGINEER
OREGON
G-4307

State Well No. 16/3W-30K

(1) OWNER:

Name S. K. Coburn
Address R. R. 2 Box 396 - Eugene, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 231 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills knife
Size of perforations 1/4 in. by 2 in.
800 perforations from 18 ft. to 230 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 10 ft. below land surface Date 9/18/67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 400 gal./min. with 72 ft. drawdown after 4 hrs.
350 " " 15 " " 5 "
" 380 " " 60 " " 6 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number
1/4 Section 30 T. 16S R. 3W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 231 ft. Depth of completed well 231 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Loam	0	7	
Brown clay, & gravel	7	16	
Gravel & boulders	16	20	14
Brown clay-sand & gravel (small amount water)	20	50	30
Brown clay sand & gravel	50	105	40
Blue gray clay-small gravel	105	150	
Gray clay-small gravel	150	175	
Yellow brown clay	175	185	
Gray white clay	185	210	
Sand & gravel	210	228	5
Blue clay	228	231	

Work started 8/28/67 19 Completed 9/18/67 19
Date well drilling machine moved off of well 9/19/67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Bob [Signature] Date 9/19/67 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 24

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. W. Drilling and Pump Service
(Person, firm or corporation) (Type or print)

Address 2320 Main, Springfield, Ore/

[Signed] Walt Wilson
(Water Well Contractor)

Contractor's License No. 268 Date 9/22/67, 19