

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
MAY 2 1969
STATE ENGINEER
SALEM OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

LANE
7491

State Well No. 16/3W-31

State Permit No.

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion

(1) OWNER:

Name VICTOR LANINI
Address 538 WILLAMETTE NORTH STREET
COBURG OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 186 ft. Gage 250
10" Diam. from 168 ft. to 226 ft. Gage 250

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills Knife
Size of perforations 1/4 in. by 3 in.
1000 perforations from 18 ft. to 186 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 11 ft. below land surface Date 4/17/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? W.W. Drilling
Yield: 482 gal./min. with 4 ft. drawdown after 2 hrs.
533 " 5 " 3 "
675 " 9 " 4 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number
1/4 1/4 Section 31 T. 16S R. BR3 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 250 ft. Depth of completed well 250 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Existing well	0	40	11'
Brown sand gravel & clay	40	90	
gray sand gravel & clay	90	112	10'
Water streak	112	160	
Brown clay sand & gravel	160	182	10'
Water at 160	182	205	
Yellow Brown sand & gravel	182	205	9'
Sand gravel & clays	205	255	
gray color	225	250	
Blue gray clay	225	250	

Work started 4/3 1969 Completed 4/24 1969
Date well drilling machine moved off of well 4/24 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R.D. John Date 4/17 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 24

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.W. Drilling & Pump
(Person, firm or corporation) (Type or print)

Address 2320 MANN Springfield
OR.

[Signed] Walt Wilson
(Water Well Contractor)

Contractor's License No. 268 Date 4/29 1969

Existing well 10'