

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

LANE
7502

WATER WELL REPORT

STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED

FEB 28 1968

State Well No. 16/3w-31

State Permit No.

STATE ENGINEER
SALEM OREGON

(1) OWNER:

Name VICTOR LANINI
Address 538 N. WILLAMETTE
COLUMBIA ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 61 ft. to 40 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No

Type of perforator used TORCH
Size of perforations 1/4 in. by 2 in.
100 perforations from 18 ft. to 40 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Type Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 10 ft. below land surface Date 7/18/67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test 100 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County LANE Driller's well number
1/4 1/4 Section 31 T. 16S. 19W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
<u>LOAM</u>	<u>0</u>	<u>7</u>	
<u>SAND & GRAVEL WITH CLAY</u>	<u>7</u>	<u>18</u>	
<u>SAND - GRAVEL WATER BEARING</u>	<u>18</u>	<u>30</u>	<u>10'</u>
<u>SAND & GRAVEL - CLAY</u>	<u>30</u>	<u>40</u>	

Work started 7/14 1967 Completed 7/18 1967
Date well drilling machine moved off of well 7/18 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 7/19, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 24

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.W. DRILLING & PUMP
(Person, firm or corporation) (Type or print)

Address 2320 MAIN - Spfld.

[Signed] Walt Wilson (Water Well Contractor)

Contractor's License No. 268 Date 8/1, 1967