RECEIVED
SEP 14 1959
ENGINEER

LANE 7556

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 16/3W-32A

State Permit No.

(1) OWNER:
Name CITY OF COBURG
Address COBURG ORE

(2) LOCATION OF WELL:
County LANE Owner's number, if any—
NE ¼ of NE ¼ Section 32 T. 16S R. 3W W.M.
Bearing and distance from section or subdivision corner
¼ mile West of City of Coburg Well Bears South 60° E 1431 ft. from the SW Corner of the Isaac VanDemark D.L.C.

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 46 ft. Gage Henry
10" Diam. from 46 ft. to 23 ft. Gage Henry
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used
SIZE of perforations in. by in.
perforations from 26' ft. to 70' ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by: CITY of COBURG
[Signed] Raleigh E Manby (Owner) Date 9/6, 1959
MAYOR

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? RAMSEY-WAITE Co.
Yield: 279 gal./min. with 60 ft. drawdown after 5 hrs.
" Test made in May 1959
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well inches.
Depth drilled ft. Depth of completed well ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil	0	5
Sand & gravel	5	69

Work started 19 . Completed Sept 22 1958

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling (Person, firm, or corporation) (Type or print)
Address Rt 2 Box 695 Creswell
Driller's well number
[Signed] Dewbert S Jones (Well Driller)
License No. 103 Date 9-23, 1958

(USE ADDITIONAL SHEETS IF NECESSARY)