

RECEIVED
APR 26 1967

LANE

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE ENGINEER WATER WELL REPORT
STATE OF OREGON
(Please type or print)

7626

State Well No. 16/3W-32
State Permit No.

(1) OWNER:

Name AGNES ADAIR
Address R. 2
Co Burg - OREGON

(2) LOCATION OF WELL:

County LANE Driller's well number 3
1/4 Section 32 T. 16 S R. 4 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 167 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS KNIFE
Size of perforations 1/4 in. by 2 in.
240 perforations from 35 ft. to 65 ft.
240 perforations from 85 ft. to 130 ft.
90 perforations from 130 ft. to 167 ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 18 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 1 ft. 6" ft. below land surface Date 2/21/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? W.W. Drilling
Yield: 550 gal./min. with 45 ft. drawdown after 2 hrs.
" 300 " 42 " 3 "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 185 ft. Depth of completed well 185 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
LOAN - BEA GRAVEL	0	8
SAND & GRAVEL - CLAY (WATER)	8	28
CLAY - GRAVEL - CEMENTED	28	30
SAND - GRAVEL - (WATER)	30	35
CEMENTED GRAVEL - HARD	35	40
SAND - GRAVEL - CLAY	40	65
Light GRAY CLAY - BEA GRAVEL (NO WATER)	65	96
DARK BROWN CLAY - BEA GRAVEL (NO WATER)	96	120
LT. GRAY CLAY - VERY LITTLE GRAVEL	120	140
CLAY - SAND - GRAVEL (LOTS OF WATER)	140	148
SAND - GRAVEL - CEMENTED	148	183
LT. GRAY CLAY - INTO BROWN CLAY	183	185

Work started 2/1 1967 Completed 2/21 1967
Date well drilling machine moved off of well 2/21 1967

(13) PUMP:

Manufacturer's Name H.P.
Type:

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.W. Drilling (Person, firm or corporation) (Type or print)
Address 2320 MAIN ST SPTLD-OR
Drilling Machine Operator's License No. 24
[Signed] Walt Wilson (Water Well Contractor)
Contractor's License No. 268 Date 3/22, 1967