

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

LANE
7628

WATER WELL REPORT RECEIVED

STATE OF OREGON FEB 28 1967 State Well No. 16/3w-32
(Please type or print)
(Do not write above this line) STATE ENGINEER State Permit No.
OREGON

(1) OWNER:

Name GREEN BROS
Address Rt 2 EUGENE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from 71 ft. to 216 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used MILKS
Size of perforations 3/8 in. by 2 1/2 in.
405 perforations from 20 ft. to 80 ft.
84 perforations from 82 ft. to 101 ft.
105 perforations from 112 ft. to 164 ft.
16 perforations from 188 ft. to 191 ft.
22 perforations from 193 ft. to 198 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 11 ft. below land surface Date 10-6-67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? DALLER
1: 125 gal./min. with 11 ft. drawdown after 1 hrs.
2: 600 " air lift " " 2 "
" " " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used pentonite
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 13 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County LANE Driller's well number
1/4 1/4 Section 32 T. 16 R. 3 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 216 ft. Depth of completed well 216 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
SOIL	0	8	
SAND & GRAVEL	8	39	14
SAND & GRAVEL w/CLAY	39	50	
SAND & GRAVEL	50	70	30
SAND & GRAVEL w/CLAY	70	80	
SAND w/CLAY	80	87	
SAND & GRAVEL w/CLAY	87	85	
SAND w/CLAY & GRAVEL	85	101	
SAND w/CLAY SAND	101	112	25
SAND & GRAVEL w/CLAY	112	161	
SAND & GRAVEL w/CLAY LOOSE	161	164	
CLAY w/GRAVEL	164	180	
SAND w/GRAVEL	180	188	
SAND & GRAVELS	188	191	
SAND w/CLAY	191	192-6	
SAND & GRAVEL w/CLAY	192	198	
CLAY	198	203	
SAND w/CLAY & GRAVELS	203	216	

Work started 10-13 1967 Completed 11-6 1967
Date well drilling machine moved off of well 11-6 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Carl Petersen Date 12-18, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 386

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME MARIE CHRISTENSEN
(Person, firm or corporation) (Type or print)
Address 3550 W 18th Eugene
[Signed] Marie Christensen
(Water Well Contractor)
Contractor's License No. 97 Date 12-18, 1967