

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the  
WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**LANE 7642**  
**RECEIVED**  
WATER WELL REPORT  
STATE OF OREGON  
SEP 14 1978  
(Please print)

*LANE NC 7642*  
State Well No. 165/30-33c  
State Permit No. \_\_\_\_\_

SALEM, OREGON

**(1) OWNER:**

Name Vira Corporation - Gallon House (RW)  
Address 2095 Wood Acres Drive  
Eugene, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Cable  Dug   
Driven  Jetted  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
OD 5" Diam. from 325 ft. to 625 ft. Gage 10

**(6) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used Torch (Liner Only)  
Size of perforations 3/8 in. by 3 in.  
352 perforations from 325 ft. to 625 ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Air  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 25 gal./min. with 400 ft. drawdown after 2 hrs.  
Bailer test -0- gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 51 Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Existing Seal Not Distrubed  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Diameter of well bore below seal \_\_\_\_\_ in.  
Number of sacks of cement used in well seal \_\_\_\_\_ sacks  
How was cement grout placed? \_\_\_\_\_  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Lane Driller's well number 2281/CP670  
1/4 SW 1/4 Section 33 T. 16 R. 3W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 246 ft.  
Static level 26 ft. below land surface. Date 8/25/78  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
Depth drilled 210 ft. Depth of completed well 415 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Blue Shale	415	625	26
See Previous Log - Dated 5/16/78			

Work started 8/25/ 19 78 Completed 8/25/ 19 78  
Date well drilling machine moved off of well 8/25/ 19 78

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Arthur N. Lewis Date 8/25/ 19 78  
( Drilling Machine Operator )  
Drilling Machine Operator's License No. 717

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Carter's Drilling & Pump Service  
(Person, firm or corporation) (Type or print)  
Address P.O. Box 16 Springfield, Oregon 97177  
[Signed] James J. Carter  
(Water Well Contractor)  
Contractor's License No. 126 Date 8/25/ 19 78

LANE 7642



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.oregon.gov/owrd

Application for
Well ID Number

RECEIVED

Do not complete if the well already has a Well Identification Number.

JAN 20 2022

OWRD

I. OWNER INFORMATION

Current Owner Name (please print): Premier RV Park

Mailing Address: 33022 Van Duyn Road

City, State, Zip: Eugene, Oregon, 97408

Mail Well ID to: [X] SAME AS ABOVE [ ] In Care Of (C/O)

Name & Address:

City, State, Zip:

II. WELL LOCATION INFORMATION (Please fill out as completely as possible)

Township: 16 S (North / South) Range: 3 W (East / West) Section: 33 SE 1/4 of the NE 1/4

Tax Lot (usually last 3-5 numbers of Tax Map #): 100 County Lane

GPS Coordinates: 44.13694749, -123.04855552

Street Address of Well, City: 33022 Van Duyn Road, Eugene

If the property had a different street address in the past: N/A

III. GENERAL WELL INFORMATION (Please fill out as completely as possible, AND attach copy of Well Report, if available)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): Commercial

Date Well Constructed (or property built): 5-16-78 Total Well Depth: 625 ft Casing Diameter: 6 inch

Owner at time the well was constructed (if known): Vira Corporation (Gallon House) Well Report # (if known): LANE 735 & 7642

Other Information: Permit G-13447

SUBMITTED BY (please print): Joseph French (EGR and Associates)

PHONE: 541-688-8322 EMAIL &/or FAX: jfrench@egrassoc.com

To send the completed application, you may MAIL it to: Oregon Water Resources Dept. 725 Summer St NE, Suite A, Salem, Oregon 97301. Or EMAIL the completed PDF form to: Ladeena.K.Ashley@oregon.gov, or FAX it to: (503) 986-0902.

For Official Use Only by the Oregon Water Resources Department:

Received Date:

1-20-22

Well Report Number:

LANE 735 (ORIG)
LANE 7642 (DEEPEN)

Well Identification #:

L-145901