

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

LANE  
7756

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)  
(Do not write above this line)

RECEIVED  
FEB 28 1967

State Well No. 16/400-5  
Permit No.

(1) OWNER:

Name CARY STROME  
Address JUNCTION CITY - ORE.

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 111 ft. Gage # 250  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name .....  
Type ..... Model No. ....  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

(8) WATER LEVEL: Completed well.

Static level 15 ft. below land surface Date 11/1/67  
Artesian pressure ..... lbs. per square inch Date .....

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: 600 gal./min. with 35 ft. drawdown after 4 hrs.  
500 " " 30 " " 3 "  
" 400 " " 28 " " 2 "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used CEMENT-SAND  
Depth of seal 20 ft.  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth .....  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.

(11) LOCATION OF WELL ON

County LANE Driller's well number  
1/4 Section 5 T. 16S R. 4W W.M.  
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 111 ft. Depth of completed well 111 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
LOAM	0	2	
Lt. GRAY CLAY - SMALL GRAVEL	2	25	
BROWN CLAY & GRAVEL	25	35	
CLAY & GRAVEL - REDDISH BROWN	35	50	
BLUE CLAY	50	65	
Blue CLAY - SANDY	65	70	15
BLACK SOFT - SANDY CLAYSTONE	70	82	
DARK COARSE SAND	82	95	
Blue CLAY - SANDY	95	111	

Work started 10/16 1967 Completed 10/31 1967  
Date well drilling machine moved off of well 10/11 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] D. D. John Date 11/2 1967  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 24

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.W. Drilling & Pump Ser.  
(Person, firm or corporation) (Type or print)

Address 2320 MAIN - SPALD-OR

[Signed] Walt Wilson  
(Water Well Contractor)

Contractor's License No. 268 Date Dec. 7 1967