

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED PLANE 7765 11/18/9W-56
STATE OF OREGON OCT 21 1977
WATER RESOURCES DEPT.
SALEM, OREGON
State Well No. _____
State Permit No. _____
(Please type or print)
(Do not write above this line)

WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER: SALEM, OREGON

Name Trailer Town (RW)
Address 93520 Highway 99
Junction City, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(6) CASING INSTALLED:

8" Diam. from +2 ft. to 168 ft. Gage .250
6-5/8" Diam. from 164 ft. to 169 ft. Gage .250
6-5/8" Diam. from 189 ft. to 194 ft. Gage .250

(5) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name JOHNSON
Type STAINLESS STEEL Model No.
Diam. 8" Tele Slot size 40 Set from 169 ft. to 189 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Weld: gal./min. with ft. drawdown after hrs.
Bailer test 40 gal./min. with 1 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Portland Type 3 Cement
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 12 8/16 in.
Diameter of well bore below seal 8 1/2 in.
Number of sacks of cement used in well seal 17 sacks
How was cement grout placed? Pumped From Bottom Up

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 3022-22
1/4 N.W. 1/4 Section 5 T. 16 R. 4W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 166 ft.
Static level 20 ft. below land surface. Date 9/14/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing -0-
Depth drilled 194 ft. Depth of completed well 195 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	9	
Sand & Gravel	9	17	
Gravel	17	22	
Sand & Clay	22	28	
Gravel, Sand, Blue Clay	28	32	
Gravel - Clay Cemented	32	46	
Red Clay	46	55	
Sand	55	58	
Blue Clay	58	114	
Blue Clay - Red Sand	114	115	
Blue Clay	115	164	
Clean Sand - Fine Gravel	164	169	20
Sand	169	180	
Sand - Clay	180	185	
Course Sand	185	189	20
Blue Clay	189	194	

Work started 8/31/ 19 77 Completed 10/14/ 1977
Date well drilling machine moved off of well 10/14/ 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] *James J. Carter* Date 10/14/ 19 77
(Drilling Machine Operator)

Drilling Machine Operator's License No. 390

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Carter's Drilling & Pump Service
(Person, firm or corporation) (Type of print)

Address P.O. Box 46 Springfield, Oregon 97477

[Signed] *James J. Carter*
(Water Well Contractor)

Contractor's License No. 126 Date 10/14/ 19 77