

LANE 7773

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON  
within 30 days from the  
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)  
(Do not write above this line)

RECEIVED  
JUN 28 1968  
STATE ENGINEER  
SALMON OREGON  
6-4462

State Well No. 16/46-5 L  
Permit No.

RECEIVED  
AUG 13 1968  
STATE ENGINEER  
SALEM OREGON

(1) OWNER:

Name Georgia Pacific Corporation  
Address Plant-Site, Junction City  
P O Box 789, Eugene, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
D  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

8" Diam. from 0 ft. to 105 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used MILLSKIFE  
Size of perforations 1/4 in. by 3 in.  
40 perforations from 30 ft. to 36 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

level 7 ft. below land surface Date 6-19-68  
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? DRILLER  
60 gal./min. with 10 ft. drawdown after 3 hrs.  
" " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE  
Depth of seal 20' ft.  
Diameter of well bore to bottom of seal 8 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number 163  
NE 1/4 SW 1/4 Section 5 T. 16S R. 1W W.M.  
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8"  
Depth drilled 150 ft. Depth of completed well 97 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
CLAY	0	20	—
SAND-GRAVEL	20	35	5'
YELLOW-CLAY	35	50	—
BLUF-SHALE	50	97	—
FINE-SAND-BLACK	97	98	9'
BLACK-MUCK	98	150	9'

Work started 6-13 19 68 Completed 6-19 19 68  
Date well drilling machine moved off of well 6-19 19 68

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harry May Date 6-19, 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 307

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Jensen Company  
(Person, firm or corporation) (Type or print)

Address P O Box 2571, Eugene, Oregon 97102

[Signed] Gary A. Miller Owner  
(Water Well Contractor)

Contractor's License No. 179 Date 6-20-68, 19