

© Strome

LANE  
2779 well No. 4

RECEIVED  
OCT 26 1966

WATER WELL REPORT ENGINEER

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON OREGON  
(Please type or print) G 5452

State Well No. 16/4w-5  
State Permit No.

(1) OWNER:  
Name Carey L. Strome  
Address P O Box 378  
Junction City, Oregon

(2) LOCATION OF WELL:  
County Lane Driller's well number 118  
SE 1/4 SW 1/4 Section 5 T. 16S R. 1W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:  
10" Diam. from 0 ft. to 50 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used Mills Knife  
Size of perforations 1/4 in. by 1/4 in.  
1/8" perforations from 23 ft. to 38 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal Bentonite  
Depth of seal 18 ft. Was a packer used?  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from 50 ft. to 66 ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:  
Static level 14 ft. below land surface Date 10-12-66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 125 gal./min. with 10 ft. drawdown after 2 hrs.  
" " " "  
" " " "  
" " " "  
" " " "  
Baller test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 10"  
Depth drilled 66 ft. Depth of completed well 50 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Grit	0	12
Dirty sand & gravel	12	20
Gravel & sand	20	38
Clay sand & gravel	38	49
Brown sandstone soft	49	66

Work started 10-8 1966 Completed 10-12-1966  
Date well drilling machine moved off of well 10-13 1966

(13) PUMP:  
Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Miller-Jensen Company  
(Person, firm or corporation) (Type or print)  
Address P O Box 3371, Eugene, Oregon  
Drilling Machine Operator's License No. 336  
[Signed] Harry A. Miller (Water Well Contractor) Owner  
Contractor's License No. 179 Date 10-14-66, 1966

well #4