

RECEIVED

AUG 5 1966

LANE
7806

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON

(Please type or print)

G-3658

State Well No.

16/4u2-6J

State Permit No.

(1) OWNER:

Name RONALD SANDFORDAddress 199 BAILEY LN.
JUNCTION CITY ORE

(2) LOCATION OF WELL:

County LANE Driller's well number1/4 1/4 Section 6 T. 16S R. 4W W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☒
Irrigation ☒ Test Well ☐ Other ☐ Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☒ Welded ☐

3" Diam. from 0 ft. to 27 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ NoType of perforator used 1 1/2" drill

Size of perforations in. by in. 60 perforations from 24 ft. to 27 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BentoniteDepth of seal 6 ft. Was a packer used? no

Diameter of well bore to bottom of seal 6 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoWas well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 13 ft. below land surface Date 7/30/66

Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller

Yield: 80 gal./min. with 4 ft. drawdown after 2 hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 27 ft. Depth of completed well 27 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil & Brown clay	0	9
packed sand & gravel	9	19
packed sand	19	24
water bearing sand & gravel	24	27

Work started 7/29 1966 Completed 7/29 1966

Date well drilling machine moved off of well 7/30 1966

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O. B. Nye

(Person, firm or corporation)

(Type or print)

Address JUNCTION CITY OREDrilling Machine Operator's License No. 211[Signed] O. B. Nye

(Water Well Contractor)

Contractor's License No. 151 Date 7/30 1966